

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221353  
Address: 3214 SW ENOCH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Alex Fischer	Failed	Wednesday, December 13, 2023

Corrective Action Required:

1	Misc	-Remove covers for smokes -Adjust self closing hinges at garage door -Break off screw at anti siphon device at main water shutoff -Missing 1/2" through bolts at post to beam connection at deck -Missing splash pads -Missing sump pump extension -No sod installed -Missing tamper proof caps at A/C
---	------	---

Comments: