LEE'S SUMMIT
MISSOURI

DEVELOPMENT SERVICES

Residential Plan Review

December 13, 2023

ASTRAWATT SOLAR
3525 ROANOKE RD #110
KANSAS CITY, MO 64111
(816) 489-4154

Permit No:	PRRES20236319
Plan Name:	
Project Address:	257 SE COYLE DR, LEES SUMMIT, MO 64063
Parcel Number:	60240171300000000
Location:	MILL CREEK OF SUMMIT MILL 3RD PLAT LOTS 87-124 & TR F---LOT 106
Type of Work:	ALTERATION SINGLE FAMILY
Occupancy Group:	RESIDENTIAL, ONE- AND TWO-FAMILY
Description:	ROOF MOUNTED SOLAR - KW.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any qeustions you may have.

Development Services Department (816) 969-1200

Plot Plan Review	**Reviewed By:**	**Not Required**
Residential Plan Review	**Reviewed By:**	**Rejected**

1. DRAWINGS MUST BE DESIGNED IF THE SYSTEM IS OVER 15KW

Fire Department Solar Review	**Reviewed By: Jim Eden**	**Approved**

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:			
Roofing Material		**Number of Bathrooms**	
Number of Bedrooms		**Number of Stories**	
Number of Living Units		**Total Living Area**	