

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233392

Address: 3746 SW CLAYTON PL, LEES SUMMIT, MO 640823744 SW CLAYTON PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Not Ready	Tuesday, December 12, 2023

Corrective Action Required:

1	Misc	-Break off security screw at anti siphon device in basement -Adjust self closing hinges at garage door -Caulk missing at the tops of exterior lights next to garage -Sod too close to exterior siding at rear of house -Grading at north side of house appears to be running towards the house
---	------	--

Corrective Action Required:

2	Misc	None of the deficiencies from the previous inspections have been addressed.
---	------	---

PLEASE WALK PROPERTIES BEFORE SCHEDULING ANY FURTHER INSPECTIONS

Comments: