

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231099
Address: 1001 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Friday, December 15, 2023

Corrective Action Required:

1	Misc	-Provide knockout cover, remove dead mc and install knockout cover at end of hallway. **OK TO COVER OTHER AREAS, WILL CHECK AT FINAL
---	------	---

Comments: