

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232039

Address: 1001 NW CHIPMAN RD, Unit:123, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Friday, December 15, 2023

Corrective Action Required:

1	Misc	Hard lids ok to cover -MC not allowed above drop ceiling per NEC 334.12
---	------	--

**Comments:**