

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231814
Address: 2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Fire Line - Hydrostatic Test	Nick Scott	Passed	Tuesday, November 14, 2023

Informational:

1	Misc	11-10-23 DS Site visited for a pressure test and it failed after losing 5 psi in two hours.
		11-13-23 NS Site visited for a pressure test and it passed. The contractor found that one of the fittings on the pipe was leaking.

Comments: