

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234931
Address: 1155 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Friday, December 15, 2023

Corrective Action Required:

1	Misc	-Provide wye fitting at vertical-horizontal connection (below north restroom floor) -Provide continuous gravel support of underslab drain. Make sure drain piping is sloped per code -Vent mop sink or eliminate -Plan shows 8" underground pvc exhaust pipe for pedicure and nail table. See M200
---	------	---

Comments: