

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Not Ready	Monday, December 18, 2023

Corrective Action Required:

1	Misc	-Missing handrail at garages stairs -Adjust self closing hinges at garage stairs -Missing center bracket at hand rail going upstairs -Break off tamper proof screw at anti siphon device in basement
---	------	---

Comments: