

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221049
Address: 808 NE ALGONQUIN ST, LEES SUMMIT, MO 64064806 NE ALGONQUIN ST, LEES SUMMIT, MO 64064804 NE ALGONQUIN ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Not Ready	Tuesday, December 19, 2023

Corrective Action Required:

1	Misc	Complete underground gas lines. Pressure test of indoor gas piping ok
		**12/18-Not ready fee assessed. Complete the underground gas line and call for an inspection
		**12/19-Not ready fee assessed. Please complete the underground gas line and call for an inspection

Comments: