

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO
640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Khanh Nguyen	Not Ready	Tuesday, December 19, 2023

Corrective Action Required:

1	Misc	No pressure on all the gauges, except 4021. Install working gauges and provide verification of min 12" burial depth of underground gas lines
---	------	--

****12/18-**Not ready fee assessed. Gas lines still not pressurized

****12/19-**Not ready fee assessed. Except for unit 4021, all other unit gas line pressure gauges are at zero pressure. Shall check for gas line leakage.

Underground gas lines shall be verified for min 12" burial depth

Comments: