

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233310

Address: 3745 SW CLAYTON PL, LEES SUMMIT, MO 640823743 SW CLAYTON PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Tuesday, December 19, 2023

Corrective Action Required:

2	Miscellaneous Correction	3743 When filling in low spots in the sod, it raised the yard level within 1 1/2 inches of the exterior siding. Code allows a 6 inch height difference between the sod and the exterior siding
---	--------------------------	---

3745
Passed for full CofO

KBEARD 12/19/23

Comments: