

# CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street

Lee's Summit, MO 64063

(816) 969-1200

Fax (816) 969-1201

## PLAN REVIEW CONDITIONS

August 03, 2011

BURDG DUNHAM & ASSOC  
920 S HUGHES  
HAMILTON MO, MO 64644

Permit No: PRCOM20113619  
Project Title: MAURICES - SUMMIT FAIR  
Project Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086  
Parcel Number: 51700033300000000  
Location: SUMMIT FAIR LOTS 22A & 24A---LOT 22A  
Type of Work: New Tenant Finish  
Occupancy Group: MERCANTILE  
Description: TENANT FINISH FOR CLOTHES RETAIL

*The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.*

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

### **Building Plan Review**

**Reviewed By: Michael Weisenborn**

**Approved**

3. 2006 IPC 403.4 - Required public toilet facilities. Customers, patrons and visitors shall be provided with public toilet facilities in structures and tenant spaces intended for public utilization. The accessible route to public facilities shall not pass through kitchens, storage rooms, closets or similar spaces. Employees shall be provided with toilet facilities in all occupancies. Employee toilet facilities shall be either separate or combined employee and public toilet facilities.

Action required - This comment is for information purposes.

10. The bottom chord braces at the rtu(s) shall be welded once the units have been installed. This will need to be verified by the city inspection staff.

Action required - This comment is for information purposes.

### **Fire Plan Review**

**Reviewed By: Brian Austerman**

**Approved**

1. 2006 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

2. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

Action required: Provide shop drawings for review and approval.

3. 1006.3 Illumination emergency power.

The power supply for means of egress illumination shall normally be provided by the premises' electrical supply. In the event of power supply failure, an emergency electrical system shall automatically illuminate the following areas:

1. Aisles and unenclosed egress stairways in rooms and spaces that require two or more means of egress.
2. Corridors, exit enclosures and exit passageways in buildings required to have two or more exits.
3. Exterior egress components at other than the level of exit discharge until exit discharge is accomplished for buildings required to have two or more exits.
4. Interior exit discharge elements, as permitted in Section 1024.1, in buildings required to have two or more exits.
5. Exterior landings, as required by Section 1008.1.5, for exit discharge doorways in buildings required to have two or more exits.

The emergency power system shall provide power for a duration of not less than 90 minutes and shall consist of storage batteries, unit equipment or an on-site generator. The installation of the emergency power system shall be in accordance with Section 2702 of the International Building Code.

Action required: Provide exterior emergency lighting. RESOLVED ON RESUB

ADDITIONAL ACTION REQUIRED: PROVIDE EMERGENCY LIGHTING IN STOREROOM, VERIFIED AT INSPECTION

4. 2006 IFC 906.2 - General requirements. Portable fire extinguishers shall be selected, installed and maintained in accordance with this section and NFPA 10.

Provide a minimum of 2, 2A:10B:C fire extinguishers in conspicuous locations and in a normal path of travel. Verified at inspection.

5. Duct Detection- Duct detectors shall be connected to the building alarm system and give a supervisory signal only without activation of interior horn/strobes. RESOLVED ON RESUB

6. 2006 IFC 505.1- Address numbers. New and existing buildings shall have approved address numbers, building numbers or approved building identification placed in a position that is plainly legible and visible from the street or road fronting the property. These numbers shall contrast with their background. In Multi-tenant commercial building where tenants have multiple entrances located on different sides of the building, each door shall be addressed. Address numbers shall be Arabic numerals or alphabet letters. Numbers shall be a minimum of 4 inches (102 mm) high with a minimum stroke width of 0.5 inch (12.7 mm).

PROVIDE ADDRESSING ON ALL EXTERIOR DOORS LEADING INTO THE SPACE, VERIFIED AT INSPECTION

- Approved to issue per the listed conditions.  
 Do not issue per the listed conditions.  
 Approved to construct foundation only per the listed conditions.

\_\_\_\_\_ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

\_\_\_\_\_  
Signature of Applicant

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Applicant Name

\_\_\_\_\_  
CompanyName

***The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.***

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***