

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232220
Address: 3254 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Wednesday, December 20, 2023

Corrective Action Required:

1	Misc	- anchor steel columns in basement - No fire blocking done in basement (at top plate on exterior walls, fire blocking every 10' vertical on exterior walls) - Missing nails in joist hangers at garage
---	------	--

Comments: