

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# Temporary Certificate of Occupancy

---

**Permit #:** PRCOM20214608  
**Address:** 916 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081918 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081920 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081922 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081924 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081926 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081928 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081914 NW BLACK TWIG CIR, LEES SUMMIT, MO 64081  
**Inspected On:** Monday, May 22, 2023  
**Inspected By:** Robb Popp  
**Expiration Date:** 6/21/2023 12:00:00 AM

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Robb Popp	Pending	

**Corrective Action Required:**

1 Misc Final grade/sod  
-siding requires 6" clearance to grade

Foundation drainage must extend 36" from foundation