

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20192646  
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Robb Popp	Failed	Wednesday, December 20, 2023

Corrective Action Required:

1	Misc	-Exterior soffif framing ok **Leave back open to inspect electrical once installed  -Breezway hard lid ok to cover -Hard lids at first floor lobby west building  12/20/23 -complete hvac at second floor hard lids
---	------	--

**Comments:**