

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231910
Address: 2622 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, December 22, 2023

Corrective Action Required:

1	Misc	-obtain issued lawn irrigation permit -sod -slash blocks and sump pump discharge -will check water meter at time of sod -whirlpool bathtub pump access opening to be 12"x12" or 18"x18" if more than 24" from opening -spark rings where as required in basement wet bar area -(2) 1/2" through bolts at deck post to beam connections
---	------	--

Comments: