

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20225393  
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Mitchell Schwarz	Partial	Friday, December 22, 2023

Corrective Action Required:

1	Misc	First layer, screw pattern walls under stairs Fire caulking directly under stairs  1st, 2nd and 3rd layer under stairs ceiling  1st layer elevator
---	------	---

**Comments:**