

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231595
Address: 3246 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Alex Fischer	Failed	Friday, December 22, 2023

Corrective Action Required:

1	Misc	-Missing bonding screw in main panel -Plastic bushing damaged/loose at top right corner of main panel
---	------	--

Comments: