

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233615

Address: 2140 SW OSAGE DR, LEES SUMMIT, MO 640822142 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Failed	Friday, December 22, 2023

Informational:

1	Miscellaneous Correction	Full erosion control is in place at the time of sewer inspection. Full erosion control must be in place until occupancy.
---	--------------------------	--

Partial Correction:

2	Miscellaneous Correction	Erosion control has been knocked down and needs to be repaired or replaced. Full erosion control must be maintained until full CO. Remove all gravel and dirt from the street. No inspections will be completed until full erosion control is in place and maintained. 08/29/2023 KBEARD
---	--------------------------	---

Corrective Action Required:

3	Miscellaneous Correction	Some erosion control has been knocked down and needs to be repaired or replaced. Grave needs to be added to the front of the lot so mud does not enter the street. Full erosion control must be maintained until full CO.
---	--------------------------	---

Comments: