

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231595
Address: 3246 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Alex Fischer	Failed	Friday, December 22, 2023

Corrective Action Required:

2	Misc	-Missing fire blocking at top plate next to sliding doors -Missing fire blocking top plate laundry -Missing joist hanger above kitchen area -Missing fire blocking at wire chase behind master shower top and bottom -Missing anchor bolts east side under porch -Missing joist hanger at double LVL entry from garage
---	------	---

Comments: