

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215211

Address: 4023 NE SAGAMORE DR, LEES SUMMIT, MO 640644025 NE SAGAMORE DR, LEES SUMMIT, MO
640644027 NE SAGAMORE DR, LEES SUMMIT, MO 640644021 NE SAGAMORE DR, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Khanh Nguyen	Failed	Friday, December 22, 2023

Corrective Action Required:

1	DCM5 ESC INSP DENIED	**PROVIDE EROSION CONTROL ALONG THE STREET AND CREEK AT REAR OF LOT
---	-------------------------	--

**CLEAN STORM INLET AT FRONT

**NO FURTHER INSPECTION IF EROSION CONTROL IS NOT IN COMPLIANCE

Comments: