

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232420
Address: 3108 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Partial	Wednesday, December 27, 2023

Corrective Action Required:

1	Misc	12-18-23 Dustin A, Dw is formed and aggregate is compacted. Will need to keep ADA slopes through approach. Approved to pour. 12-27-23 Dustin A, dw poured, slopes are in compliance forms still need to be pulled
---	------	--

Comments: