

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, Unit:IR, LEES SUMMIT,  
MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Sediment Control (ESC) Inspection</b>	John Jackson	Partial	Thursday, December 28, 2023

Informational:

1	Misc	09/06/23 Wednesday JMJ Erosion control appears to be functioning properly.
---	------	---

		09/12/23 Wednesday JMJ Erosion control appears to be functioning properly.
--	--	---

Corrective Action Required:

2	Misc	09/25/23 Monday JMJ ( KADEAN )
---	------	--------------------------------

Erosion control failure.  
The grounds around building one have been grade but no vegetation has been established. After the weekend rains there are area the Southside from East to West that have silt in drive and parking lot area.

Informational:

3	Misc	12/28/23 Thursday JMJ Erosion control appears to be functionable.
---	------	--

**Comments:**