

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233425  
Address: 2735 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Alex Fischer	Failed	Thursday, December 28, 2023

Corrective Action Required:

2	Misc	-Anchor bolts in garage not in center 1/3 -Missing snow blocking in garage north west wall -Missing joist hanger in laundry -Missing collar ties bedroom 2 -Missing fire blocking top plate south wall basement bathroom -Missing joist hangers at deck -Secure NM cable at right side at fireplace
---	------	---

**Comments:**