Michael L. Parson

Sandra K. Karsten Director, Public Safety

J. Tim Bean State Fire Marshal



205 Jefferson Street, Suite 1315 Mailing Address: P.O. Box 844 Jefferson City, MO 65102 Telephone: (573) 751-2263 Fax: (573) 526-5971

Email: Ashley.Temmen@dfs.dps.mo.gov Madison.Smith@dfs.dps.mo.gov

Missouri Department of Public Safety Division of Fire Safety

November 14, 2023

William D Zarr 1549 East 559th Road Brighton, MO 65617

New Installation Permit

Agent

William D Zarr 1549 East 559th Road Brighton, MO 65617

Owner

City of Lee's Summit 220 SE Green St Lee's Summit, MO 64063

Equipment State ID #26563

Type: LU\LA Traction Speed: 25 Capacity: 1400 Manufacturer: Savaria Serial Number: 470294 ApprovedDate: 11/14/2023 Architect

GLMV Architecture (816) 444-4200

Location #15741

Fire Station #4 5031 NE Lakewood Way Lee's Summit, MO 64064

General Contractor

mcCownGordon Construction 850 Main Street Kansas City, MO 64105

Equipment Contractor

Country Home Elevator and Stair Lift

1549 East 559th Road Brighton, MO 65617

This is to certify that all plans and information required by the board have been submitted and clearly demonstrates that the installation or major alteration shall be constructed and installed in conformity with the standards prescribed in the American Society of Mechanical Engineers, ASME A17.1, Safety Code of Elevators and Escalators, American National Standard Safety Code for Manlifts ANSI A90.1, American National Safety Code for Personnel Hoist ANSI A10.4 latest version adopted and amended by the Elevator Safety Rules and Regulations, RSMo 701.350 through 701.380 and 11CSR 40-5.010 through 40-5.150.

Limited Use/ Limited Application Elevator Alteration (LU/LA) (A17.1-2016 Section 5.2), Sprinklers located Elevator Lobby work space areas shall comply with A17.1-2016 2.8.3.3.2, A117.1-2009 Section 407 Elevators

Deputy Chief Elevator Inspector

State Fire Marshal