

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233908
Address: 2731 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, January 03, 2024

Corrective Action Required:
3 Misc

- fireblock N garage wall to under stairs and ceiling space
- fireblock dead space in mud hall to ceiling. Space.
- secure csst in mud hall dead space
- fireblock N great room wall to furr down
- fireblock fireplace/master suite wall to ceiling space
- double joist missing above sw basement
- security blocking basement door
- anchor bolt missing at plate break Ne basement
- sister all over notched studs for anchor bolts in basement

Comments: