

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234777  
Address: 2615 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Wednesday, January 03, 2024

Informational:

1 Misc

PORTAL FRAME AND CS-PS APPROVED TO COVER.

Corrective Action Required:

2 Misc

- anchor bolts to be in the middle 1/3 of sill plate. See garage portal
- seal bottom plate penetrations in bed 2
- add studs at exterior wall corner in bed 2 entry
- nail exterior wall corners to code
- fireblock stairwell wall to ceiling space
- fireblock bed 3 S wall
- header joints at bed 4 entry

Address ufer ground (confirm connection to ufer not anchor bolt, connection must remain accessible)

**Comments:**