

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234777
Address: 2615 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, January 03, 2024

Informational:

1 Misc

PORTAL FRAME AND CS-PS APPROVED TO COVER.

Corrective Action Required:

2 Misc

- anchor bolts to be in the middle 1/3 of sill plate. See garage portal
- seal bottom plate penetrations in bed 2
- add studs at exterior wall corner in bed 2 entry
- nail exterior wall corners to code
- fireblock stairwell wall to ceiling space
- fireblock bed 3 S wall
- header joints at bed 4 entry

Address ufer ground (confirm connection to ufer not anchor bolt, connection must remain accessible)

Comments: