

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231204
Address: 2951 SE SHENANDOAH PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Proof Roll	Bobby Richest	Partial	Wednesday, January 03, 2024

Informational:	
1 Misc	1-3-24 BR Contractor performed a proof roll on 9" chemically subgrade at the 2nd entrance approach on the parking lot on building 3 which was passed to put down 6" of asphalt base

Comments: