

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20216099
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------|
| All Rough Inspection - Residential | Khanh Nguyen | Partial | Thursday, January 04, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Rear dining CSPF walls not framed per code **Nail siding to studs @ 3" oc on both floors CSPF walls |
| | | **interior brace wall by GB method-OK |

Comments: