

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234959
Address: 2207 SW HOOK FARM DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, January 04, 2024

Informational:

1	Misc	Garage portal and rear cspf okay to cover.
---	------	--

Corrective Action Required:

4	Miscellaneous Correction	A revised engineers letter is needed for the over notched and recommended repair of the bathroom floor joist which needs to include the property address and permit number. Okay to insulate
---	--------------------------	--

Comments: