

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, January 05, 2024

Partial Correction:

1	Misc	-Missing handrail at garages stairs -Adjust self closing hinges at garage stairs -Missing center bracket at hand rail going upstairs -Break off tamper proof screw at anti siphon device in basement
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	2204 -Missing handrail at garages stairs -Adjust self closing hinges at garage stairs -Missing center bracket at hand rail going upstairs -Break off tamper proof screw at anti siphon device in basement -exterior was not ready for inspection
---	--------------------------	---

2202
-Exterior of unit was not ready for inspection

2202 passed for TCO only

Corrective Action Required:

3	Misc	-No access
---	------	------------

Comments:

