

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Friday, January 05, 2024

Informational:

1	FIRST FLOOR	-Shear wall nailing pattern and sheet rock band at stair side of Stair A1 -Sheet rock band at floor trusses stair side of Stair B1
---	-------------	---

Informational:

2	SECOND FLOOR	-Shear wall nailing patten and sheet rock band at floor trusses Stair A1
---	--------------	--

Corrective Action Required:

3	THIRD FLOOR
---	-------------

Corrective Action Required:

4	FOURTH FLOOR
---	--------------

Corrective Action Required:

5	Miscellaneous Correction	-Have design professional clarify rating and detail for stairwell walls. Life safety plan shows 1 hour rating, details call for 2 hour wall where 4 or more floors connected
---	--------------------------	--

**Comments:**