

... Fire Protection by Computer Design

12-26-2023

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039



Job Name : Summit Square
Building :
Location : Stairwells
System : Standpipe
Contract :
Data File : Building 1 Wet Manual Standpipe.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square

Page 1
Date

City Water Supply:
C1 - Static Pressure : 150
C2 - Residual Pressure: 150
C2 - Residual Flow : 1250

Demand:
D1 - Elevation : 12.957
D2 - System Flow :
D2 - System Pressure : 134.028
Hose (Demand) : 1000
D3 - System Demand : 1000
Safety Margin : 15.972



Fittings Used Summary

Ranger Fire Inc
Summit Square

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
HV1	34.917		100.0	na	250.0			
V1	24.25		107.26	na				
HV3	47.0		91.49	na	250.0			
HV5	34.917		98.24	na	250.0			
V3	40.333		97.0	na				
X1	34.917		100.4	na				
V5	34.917		100.87	na				
HV4	34.917		103.46	na	250.0			
V4	34.917		106.1	na				
SP1	20.833		110.03	na				
SP1A	20.833		110.11	na				
SP2	20.833		110.35	na				
SP3	20.833		110.42	na				
SP3A	20.833		110.67	na				
SP4	20.833		110.76	na				
SP4X	20.833		113.48	na				
SP5	20.833		118.42	na				
SP6	20.833		121.48	na				
SP7	20.833		123.18	na				
SP8	10.25		128.55	na				
TOS	10.25		129.37	na				
BOS	5.0		132.85	na				
FDC	5.0		134.03	na				

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV1 and V1

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square

Page 4
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HV1 to V1	250.00 250.0	2.469 100.0 0.3018	1T	8.564 0.0 0.0	0.167 8.564 8.731	100.000 4.620 2.635			Qa = 250 Vel = 16.75	
	0.0 250.00					107.255			K Factor = 24.14	
V1 to SP1	250.00 250.0	4.26 120.0 0.0151	4E 1B	52.668 15.8 0.0	17.001 68.468 85.469	107.255 1.480 1.292			Vel = 5.63	
	0.0 250.00					110.027			K Factor = 23.83	
HV3 to V3	250.00 250.0	2.469 120.0 0.2155	1T	12.0 0.0 0.0	0.167 12.000 12.167	91.487 2.887 2.622			Qa = 250 Vel = 16.75	
	0.0 250.00					96.996			K Factor = 25.38	
HV5 to V5	250.00 250.0	2.469 100.0 0.3018	1T	8.564 0.0 0.0	0.167 8.564 8.731	98.238 0.0 2.635			Qa = 250 Vel = 16.75	
	0.0 250.00					100.873			K Factor = 24.89	
V3 to X1	250.00 250.0	4.26 100.0 0.0212	1E	9.397 0.0 0.0	40.333 9.397 49.730	96.996 2.346 1.053			Vel = 5.63	
X1 to V5	0.0 250.0	4.26 120.0 0.0151	1E 1B	13.167 15.8 0.0	2.667 28.967 31.634	100.395 0.0 0.478			Vel = 5.63	
V5 to SP4	250.00 500.0	4.26 120.0 0.0545	1E 1T 1B	13.167 26.334 15.8	14.084 55.301 69.385	100.873 6.100 3.783			Vel = 11.25	
	0.0 500.00					110.756			K Factor = 47.51	
HV4 to V4	250.00 250.0	2.469 100.0 0.3019	1T	8.564 0.0 0.0	0.167 8.564 8.731	103.460 0.0 2.636			Qa = 250 Vel = 16.75	
V4 to SP4X	0.0 250.0	4.26 120.0 0.0151	2T 1B	52.668 15.8 0.0	16.500 68.468 84.968	106.096 6.100 1.284			Vel = 5.63	
	0.0 250.00					113.480			K Factor = 23.47	
SP1 to SP1A	250.00 250.0	6.357 120.0 0.0022	1T	37.72 0.0 0.0	1.917 37.720 39.637	110.027 0.0 0.086			Vel = 2.53	
SP1A to SP2	0.0 250.0	6.357 120.0 0.0021	1T	37.72 0.0 0.0	71.750 37.720 109.470	110.113 0.0 0.235			Vel = 2.53	
SP2 to SP3	0.0 250.0	6.357 120.0 0.0022	1E	17.603 0.0 0.0	16.917 17.603 34.520	110.348 0.0 0.075			Vel = 2.53	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP3 to SP3A	0.0 250.0	6.357 120.0 0.0021	1T	37.72 0.0 0.0	77.250 37.720 114.970	110.423 0.0 0.247			Vel = 2.53	
SP3A to SP4	0.0 250.0	6.357 120.0 0.0022	1T	37.72 0.0 0.0	2.000 37.720 39.720	110.670 0.0 0.086			Vel = 2.53	
SP4 to SP4X	500.00 750.0	6.357 120.0 0.0164	1T	37.72 0.0 0.0	128.083 37.720 165.803	110.756 0.0 2.724			Vel = 7.58	
SP4X to SP5	250.00 1000.0	6.357 120.0 0.0280	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	113.480 0.0 4.936			Vel = 10.11	
SP5 to SP6	0.0 1000.0	6.357 120.0 0.0280	1T	37.72 0.0 0.0	71.750 37.720 109.470	118.416 0.0 3.063			Vel = 10.11	
SP6 to SP7	0.0 1000.0	6.357 120.0 0.0280	2E	35.205 0.0 0.0	25.417 35.205 60.622	121.479 0.0 1.696			Vel = 10.11	
SP7 to SP8	0.0 1000.0	6.357 120.0 0.0280	1E	17.603 0.0 0.0	10.583 17.603 28.186	123.175 4.584 0.788			Vel = 10.11	
SP8 to TOS	0.0 1000.0	6.357 120.0 0.0280	1E	17.603 0.0 0.0	11.833 17.603 29.436	128.547 0.0 0.824			Vel = 10.11	
TOS to BOS	0.0 1000.0	6.357 120.0 0.0280	1T	37.72 0.0 0.0	5.250 37.720 42.970	129.371 2.274 1.202			Vel = 10.11	
BOS to FDC	0.0 1000.0	6.357 120.0 0.0280	1S	40.235 0.0 0.0	2.000 40.235 42.235	132.847 0.0 1.181			Vel = 10.11	
	0.0 1000.00					134.028			K Factor = 86.38	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square
Building :
Location : Stairwells
System : Standpipe
Contract :
Data File : Building 2 Wet Manual Standpipe.WXF

Water Supply Curve C

Ranger Fire Inc
Summit Square


Page 1
Date

City Water Supply:

C1 - Static Pressure : 150
C2 - Residual Pressure: 150
C2 - Residual Flow : 1250

Demand:

D1 - Elevation : 14.040
D2 - System Flow :
D2 - System Pressure : 141.678
Hose (Demand) : 1000
D3 - System Demand : 1000
Safety Margin : 8.322



Fittings Used Summary

Ranger Fire Inc
Summit Square

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
HV5	34.917		100.0	na	250.0			
HV6	24.25		104.92	na	250.0			
V5	34.917		102.64	na				
V6	24.25		107.55	na				
HV7	34.917		107.89	na	250.0			
V7	34.917		110.52	na				
HV8	34.917		108.63	na	250.0			
V8	34.917		111.26	na				
SP10	20.833		115.66	na				
SP11	20.833		117.12	na				
SP12	20.833		117.9	na				
SPX	20.833		119.91	na				
SPX1	20.833		124.82	na				
SP13	20.833		127.21	na				
SP14	20.833		129.13	na				
SP15	10.25		134.5	na				
TOS	10.25		135.7	na				
BOS	1.0		141.02	na				
FDC	2.5		141.68	na				

The maximum velocity is 16.75 and it occurs in the pipe between nodes HV5 and V5

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square

Page 4
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HV5 to V5	250.00 250.0	2.469 100.0 0.3018	1T	8.564 0.0 0.0	0.167 8.564 8.731	100.000 0.0 2.635			Qa = 250	
	0.0 250.00								Vel = 16.75	
						102.635			K Factor = 24.68	
HV6 to V6	250.00 250.0	2.469 100.0 0.3018	1T	8.564 0.0 0.0	0.167 8.564 8.731	104.918 0.0 2.635			Qa = 250	
	0.0 250.00								Vel = 16.75	
						107.553			K Factor = 24.11	
V5 to V6	250.00 250.0	4.26 100.0 0.0212		0.0 0.0 0.0	14.084 0.0 14.084	102.635 4.620 0.298				Vel = 5.63
V6 to SP10	250.00 500.0	4.26 100.0 0.0764	2E 1T 1B	18.795 18.795 11.277	37.833 48.866 86.699	107.553 1.480 6.623				Vel = 11.25
	0.0 500.00					115.656			K Factor = 46.49	
HV7 to V7	250.00 250.0	2.469 100.0 0.3018	1T	8.564 0.0 0.0	0.167 8.564 8.731	107.887 0.0 2.635			Qa = 250	
									Vel = 16.75	
V7 to SP11	0.0 250.0	4.26 120.0 0.0151	2E	26.334 0.0 0.0	6.667 26.334 33.001	110.522 6.100 0.499				Vel = 5.63
	0.0 250.00					117.121			K Factor = 23.10	
HV8 to V8	250.00 250.0	2.469 100.0 0.3019	1T	8.564 0.0 0.0	0.167 8.564 8.731	108.626 0.0 2.636			Qa = 250	
									Vel = 16.75	
V8 to SP12	0.0 250.0	4.26 100.0 0.0212	2E	18.795 0.0 0.0	6.750 18.795 25.545	111.262 6.100 0.541				Vel = 5.63
	0.0 250.00					117.903			K Factor = 23.02	
SP10 to SP11	500.00 500.0	6.357 120.0 0.0078	1T	37.72 0.0 0.0	151.083 37.720 188.803	115.656 0.0 1.465				Vel = 5.05
SP11 to SP12	250.00 750.0	6.357 120.0 0.0164	1T	37.72 0.0 0.0	9.833 37.720 47.553	117.121 0.0 0.782				Vel = 7.58
SP12 to SPX	250.00 1000.0	6.357 120.0 0.0280	1T	37.72 0.0 0.0	34.000 37.720 71.720	117.903 0.0 2.006				Vel = 10.11
SPX to SPX1	0.0 1000.0	6.357 120.0 0.0280	1E 1T	17.603 37.72 0.0	120.333 55.323 175.656	119.909 0.0 4.915				Vel = 10.11
SPX1 to SP13	0.0 1000.0	6.357 120.0 0.0280	1E 1T	17.603 37.72 0.0	29.917 55.323 85.240	124.824 0.0 2.384				Vel = 10.11

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP13 to SP14	0.0 1000.0	6.357 120.0 0.0280	2E	35.205 0.0 0.0	33.500 35.205 68.705	127.208 0.0 1.923			Vel = 10.11	
SP14 to SP15	0.0 1000.0	6.357 120.0 0.0280	1E	17.603 0.0 0.0	10.583 17.603 28.186	129.131 4.584 0.788			Vel = 10.11	
SP15 to TOS	0.0 1000.0	6.357 120.0 0.0280	2E	35.205 0.0 0.0	7.583 35.205 42.788	134.503 0.0 1.197			Vel = 10.11	
TOS to BOS	0.0 1000.0	6.357 120.0 0.0280	1T	37.72 0.0 0.0	9.250 37.720 46.970	135.700 4.006 1.314			Vel = 10.11	
BOS to FDC	0.0 1000.0	6.357 120.0 0.0280	1S	40.235 0.0 0.0	6.500 40.235 46.735	141.020 -0.650 1.308			Vel = 10.11	
	0.0 1000.00					141.678			K Factor = 84.01	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section A Wet System Remote 1.WXF

Water Supply Curve C

Ranger Fire Inc
Summit Square III


Page 1
Date

City Water Supply:

C1 - Static Pressure : 62
C2 - Residual Pressure: 55
C2 - Residual Flow : 1320

Demand:

D1 - Elevation : 16.494
D2 - System Flow : 62.64
D2 - System Pressure : 54.286
Hose (Demand) : 150
D3 - System Demand : 212.64
Safety Margin : 7.475



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S1	40.583	4.4	11.6	na	14.99	0.05	225	11.6
B1	20.167		23.32	na				
S2	40.583	4.4	13.3	na	16.05	0.05	160	13.3
B2	20.167		25.41	na				
S3	40.583	4.4	13.48	na	16.15	0.05	196	10.2
B3	20.167		25.63	na				
S4	40.583	4.4	12.33	na	15.45	0.05	196	10.2
B4	20.167		24.22	na				
S5	40.583		19.04	na				
B5	20.167		27.88	na				
S10	40.583		21.38	na				
B10	20.167		30.22	na				
S11	40.583		19.87	na				
B11	20.167		28.71	na				
S12	40.583		22.08	na				
B12	20.167		30.92	na				
S13	40.583		19.04	na				
B13	20.167		27.88	na				
200	20.167		37.63	na				
200A	20.167		36.01	na				
201	20.167		26.52	na				
202	20.167		26.51	na				
203	20.167		27.88	na				
204	20.167		28.71	na				
205	20.167		30.22	na				
206	20.167		30.92	na				
206A	20.167		36.55	na				
2ND	20.167		40.01	na				
SP1	20.833		41.29	na				
SP1A	20.833		41.29	na				
SP2	20.833		41.3	na				
SP3	20.833		41.31	na				
SP3A	20.833		41.33	na				
SP4	20.833		41.34	na				
SP4X	20.833		41.36	na				
SP5	20.833		41.39	na				
SP6	20.833		41.41	na				
SP7	20.833		41.42	na				
SP8	10.25		46.01	na				
TOS	10.25		46.01	na				
BOS	5.0		48.29	na				
FLG	1.0		57.09	na				
CH1	-5.0		59.69	na				
UG1	-5.0		59.7	na	150.0			
UG2	-5.0		52.47	na				
UG3	-5.0		50.16	na				
CT1	-5.0		57.95	na				
CT2	-5.0		57.41	na				
CT3	-5.0		56.91	na				
CTY	2.5		54.29	na				

The maximum velocity is 13.61 and it occurs in the pipe between nodes CT3 and UG1

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S1 to B1	14.99	0.874 150.0	1O	3.0 0.0	20.416 3.000	11.602 8.842			K Factor = 4.40	
B1 to 202	14.99	0.1228		0.0	23.416	2.876			Vel = 8.02	
B1 to 202	0.0	0.874 150.0	1N 1O	7.0 3.0	16.000 10.000	23.320 0.0				
	14.99	0.1228		0.0	26.000	3.194			Vel = 8.02	
	0.0 14.99					26.514			K Factor = 2.91	
S2 to B2	16.05	0.874 150.0	1O	3.0 0.0	20.416 3.000	13.300 8.842			K Factor = 4.40	
B2 to 201	16.05	0.1394		0.0	23.416	3.264			Vel = 8.58	
B2 to 201	0.0	0.874 150.0	1O	3.0 0.0	5.000 3.000	25.406 0.0				
	16.05	0.1393		0.0	8.000	1.114			Vel = 8.58	
	0.0 16.05					26.520			K Factor = 3.12	
S3 to B3	16.15	0.874 150.0	1O	3.0 0.0	20.416 3.000	13.480 8.842			K Factor = 4.40	
B3 to 201	16.15	0.1411		0.0	23.416	3.305			Vel = 8.64	
B3 to 201	0.0	0.874 150.0	1O	3.0 0.0	3.333 3.000	25.627 0.0				
	16.15	0.1410		0.0	6.333	0.893			Vel = 8.64	
	0.0 16.15					26.520			K Factor = 3.14	
S4 to B4	15.45	0.874 150.0	1O	3.0 0.0	20.416 3.000	12.332 8.842			K Factor = 4.40	
B4 to 202	15.45	0.1300		0.0	23.416	3.044			Vel = 8.26	
B4 to 202	0.0	0.874 150.0	1N 1O	7.0 3.0	7.667 10.000	24.218 0.0				
	15.45	0.1300		0.0	17.667	2.296			Vel = 8.26	
	0.0 15.45					26.514			K Factor = 3.00	
S5 to B5	0.0	0.874 150.0	1O	3.0 0.0	20.416 3.000	19.038 8.842				
B5 to 203	0.0	0.0		0.0	23.416	0.0			Vel = 0	
B5 to 203	0.0	0.874 150.0	1N 1O	7.0 3.0	9.750 10.000	27.880 0.0				
	0.0	0.0		0.0	19.750	0.0			Vel = 0	
	0.0 0.0					27.880			K Factor = 0	
S10 to B10	0.0	0.874 150.0	1O	3.0 0.0	20.416 3.000	21.381 8.842				
B10 to 205	0.0	0.0		0.0	23.416	0.0			Vel = 0	
B10 to 205	0.0	0.874 150.0	2N 1O	14.0 3.0	9.500 17.000	30.223 0.0				
	0.0	0.0		0.0	26.500	0.0			Vel = 0	
	0.0 0.0					30.223			K Factor = 0	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S11 to B11	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	19.866 8.842 0.0			Vel = 0	
B11 to 204	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	6.333 3.000 9.333	28.708 0.0 0.0			Vel = 0	
	0.0 0.0					28.708			K Factor = 0	
S12 to B12	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	22.078 8.842 0.001			Vel = 0	
B12 to 206	0.0 0.0	0.874 150.0 0.0	2O 1N	6.0 7.0 0.0	7.083 13.000 20.083	30.921 0.0 0.0			Vel = 0	
	0.0 0.0					30.921			K Factor = 0	
S13 to B13	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	19.038 8.842 0.0			Vel = 0	
B13 to 203	0.0 0.0	0.874 150.0 0.0	2N 1O	14.0 3.0 0.0	7.167 17.000 24.167	27.880 0.0 0.0			Vel = 0	
	0.0 0.0					27.880			K Factor = 0	
200 to 200A	-39.44 -39.44	1.598 150.0 -0.0389	1N	9.0 0.0 0.0	32.583 9.000 41.583	37.633 0.0 -1.619			Vel = 6.31	
200A to 201	0.0 -39.44	1.394 150.0 -0.0758	1N	8.0 0.0 0.0	117.333 8.000 125.333	36.014 0.0 -9.494			Vel = 8.29	
201 to 202	32.20 -7.24	1.394 150.0 -0.0029		0.0 0.0 0.0	2.083 0.0 2.083	26.520 0.0 -0.006			Vel = 1.52	
202 to 203	30.44 23.2	1.394 150.0 0.0284	1N	8.0 0.0 0.0	40.167 8.000 48.167	26.514 0.0 1.366			Vel = 4.88	
203 to 204	0.0 23.2	1.394 150.0 0.0284		0.0 0.0 0.0	29.167 0.0 29.167	27.880 0.0 0.828			Vel = 4.88	
204 to 205	0.0 23.2	1.394 150.0 0.0284	2N	16.0 0.0 0.0	37.417 16.000 53.417	28.708 0.0 1.515			Vel = 4.88	
205 to 206	0.0 23.2	1.394 150.0 0.0284		0.0 0.0 0.0	24.583 0.0 24.583	30.223 0.0 0.698			Vel = 4.88	
206 to 206A	0.0 23.2	1.394 150.0 0.0284	6N	48.0 0.0 0.0	150.583 48.000 198.583	30.921 0.0 5.634			Vel = 4.88	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
206A to 200	0.0 23.2	1.598 150.0 0.0146	2N 1O	18.0 8.0 0.0	47.917 26.000 73.917	36.555 0.0 1.078				
	0.0 23.20						37.633		K Factor =	3.71
200 to 2ND	62.64 62.64	2.157 120.0 0.0321	4E 1Ball 1S	24.613 2.769 13.537	33.000 40.919 73.919	37.633 0.0 2.376				
									Vel =	5.50
2ND to SP1A	0.0 62.64	2.003 150.0 0.0305	1N 1O	11.0 10.0 0.0	30.333 21.000 51.333	40.009 -0.288 1.565				
	0.0 62.64						41.286		K Factor =	9.75
SP1 to SP1A	0.0 0.0	6.357 120.0 0.0	1T	37.72 0.0 0.0	1.917 37.720 39.637	41.286 0.0 0.0				
									Vel =	0
SP1A to SP2	62.64 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	41.286 0.0 0.018				
									Vel =	0.63
SP2 to SP3	0.0 62.64	6.357 120.0 0.0002	1E	17.603 0.0 0.0	16.917 17.603 34.520	41.304 0.0 0.006				
									Vel =	0.63
SP3 to SP3A	0.0 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	77.250 37.720 114.970	41.310 0.0 0.019				
									Vel =	0.63
SP3A to SP4	0.0 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	2.000 37.720 39.720	41.329 0.0 0.007				
									Vel =	0.63
SP4 to SP4X	0.0 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	128.083 37.720 165.803	41.336 0.0 0.027				
									Vel =	0.63
SP4X to SP5	0.0 62.64	6.357 120.0 0.0002	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	41.363 0.0 0.030				
									Vel =	0.63
SP5 to SP6	0.0 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	41.393 0.0 0.018				
									Vel =	0.63
SP6 to SP7	0.0 62.64	6.357 120.0 0.0002	2E	35.205 0.0 0.0	25.417 35.205 60.622	41.411 0.0 0.010				
									Vel =	0.63
SP7 to SP8	0.0 62.64	6.357 120.0 0.0001	1E	17.603 0.0 0.0	10.583 17.603 28.186	41.421 4.584 0.004				
									Vel =	0.63
SP8 to TOS	0.0 62.64	6.357 120.0 0.0002	1E	17.603 0.0 0.0	11.833 17.603 29.436	46.009 0.0 0.005				
									Vel =	0.63
TOS to BOS	0.0 62.64	6.357 120.0 0.0002	1T	37.72 0.0 0.0	5.250 37.720 42.970	46.014 2.274 0.007				
									Vel =	0.63

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BOS to FLG	0.0 62.64	3.26 140.0 0.0032	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	48.295 8.782 0.013			* * Fixed Loss = 7.05 Vel = 2.41	
FLG to CH1	0.0 62.64	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	57.090 2.599 0.001			Vel = 0.37	
CH1 to UG1	0.0 62.64	7.68 150.0 0.0	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	59.690 0.0 0.005			Vel = 0.43	
	0.0 62.64					59.695			K Factor = 8.11	
UG1 to UG2	-931.28 -931.28	7.68 150.0 -0.0065	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	59.695 0.0 -7.228			Qa = 150 Vel = 6.45	
UG2 to UG3	0.0 -931.28	7.68 150.0 -0.0065	1T	43.857 0.0 0.0	312.417 43.857 356.274	52.467 0.0 -2.303			Vel = 6.45	
UG3 to CT1	0.0 -931.28	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	50.164 8.280 -0.498			* * Fixed Loss = 8.28 Vel = 6.45	
CT1 to CT2	0.0 -931.28	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	57.946 0.0 -0.538			Vel = 3.03	
CT2 to CT3	-212.64 -1143.92	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	57.408 0.0 -0.503			Vel = 3.73	
CT3 to UG1	0.0 -1143.92	5.86 150.0 -0.0353	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	56.905 11.248 -8.458			* * Fixed Loss = 11.248 Vel = 13.61	
	0.0 -1143.92					59.695			K Factor = -148.06	
CT2 to CTY	212.64 212.64	6.16 140.0 0.0014	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	57.408 -3.248 0.126			Vel = 2.29	
	0.0 212.64					54.286			K Factor = 28.86	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section A Wet System Remote 2.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 62
C2 - Residual Pressure: 55
C2 - Residual Flow : 1320

Demand:
D1 - Elevation : 16.494
D2 - System Flow : 61.73
D2 - System Pressure : 49.121
Hose (Demand) : 150
D3 - System Demand : 211.73
Safety Margin : 12.642



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S1	40.583		15.98	na				
B1	20.167		24.82	na				
S2	40.583		16.09	na				
B2	20.167		24.93	na				
S3	40.583		16.09	na				
B3	20.167		24.93	na				
S4	40.583		15.98	na				
B4	20.167		24.82	na				
S5	40.583		13.47	na				
B5	20.167		22.31	na				
S10	40.583	5.6	7.0	na	14.82	0.1	91	7.0
B10	20.167		18.66	na				
S11	40.583	5.6	8.36	na	16.19	0.1	98	7.0
B11	20.167		20.52	na				
S12	40.583	5.6	7.62	na	15.46	0.1	98	7.0
B12	20.167		19.51	na				
S13	40.583	5.6	7.43	na	15.26	0.1	105	7.0
B13	20.167		19.24	na				
200	20.167		32.58	na				
200A	20.167		31.47	na				
201	20.167		24.93	na				
202	20.167		24.82	na				
203	20.167		22.31	na				
204	20.167		21.85	na				
205	20.167		21.84	na				
206	20.167		22.12	na				
206A	20.167		30.9	na				
2ND	20.167		34.9	na				
SP1	20.833		36.13	na				
SP1A	20.833		36.13	na				
SP2	20.833		36.15	na				
SP3	20.833		36.16	na				
SP3A	20.833		36.17	na				
SP4	20.833		36.18	na				
SP4X	20.833		36.21	na				
SP5	20.833		36.24	na				
SP6	20.833		36.25	na				
SP7	20.833		36.26	na				
SP8	10.25		40.85	na				
TOS	10.25		40.86	na				
BOS	5.0		43.14	na				
FLG	1.0		51.93	na				
CH1	-5.0		54.53	na				
UG1	-5.0		54.54	na	150.0			
UG2	-5.0		47.31	na				
UG3	-5.0		45.0	na				
CT1	-5.0		52.78	na				
CT2	-5.0		52.24	na				
CT3	-5.0		51.74	na				
CTY	2.5		49.12	na				

The maximum velocity is 13.6 and it occurs in the pipe between nodes CT3 and UG1

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S1 to B1	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	15.982 8.842 0.0			Vel = 0	
B1 to 202	0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	16.000 10.000 26.000	24.824 0.0 0.0			Vel = 0	
	0.0 0.0					24.824			K Factor = 0	
S2 to B2	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	16.090 8.842 0.001			Vel = 0	
B2 to 201	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	5.000 3.000 8.000	24.933 0.0 0.0			Vel = 0	
	0.0 0.0					24.933			K Factor = 0	
S3 to B3	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	16.090 8.842 0.001			Vel = 0	
B3 to 201	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	3.333 3.000 6.333	24.933 0.0 0.0			Vel = 0	
	0.0 0.0					24.933			K Factor = 0	
S4 to B4	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	15.982 8.842 0.0			Vel = 0	
B4 to 202	0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	7.667 10.000 17.667	24.824 0.0 0.0			Vel = 0	
	0.0 0.0					24.824			K Factor = 0	
S5 to B5	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	20.416 3.000 23.416	13.470 8.842 0.0			Vel = 0	
B5 to 203	0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	9.750 10.000 19.750	22.312 0.0 0.0			Vel = 0	
	0.0 0.0					22.312			K Factor = 0	
S10 to B10	14.82 14.82	0.874 150.0 0.1203	1O	3.0 0.0 0.0	20.416 3.000 23.416	7.000 8.842 2.816			K Factor = 5.60 Vel = 7.93	
B10 to 205	0.0 14.82	0.874 150.0 0.1202	2N 1O	14.0 3.0 0.0	9.500 17.000 26.500	18.658 0.0 3.186			Vel = 7.93	
	0.0 14.82					21.844			K Factor = 3.17	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S11 to B11	16.19	0.874 150.0 0.1417	1O	3.0 0.0 0.0	20.416 3.000 23.416	8.363 8.842 3.319			K Factor = 5.60	
B11 to 204	0.0	0.874 150.0 0.1418	1O	3.0 0.0 0.0	6.333 3.000 9.333	20.524 0.0 1.323			Vel = 8.66	
	0.0 16.19					21.847			K Factor = 3.46	
S12 to B12	15.46	0.874 150.0 0.1301	1O	3.0 0.0 0.0	20.416 3.000 23.416	7.620 8.842 3.046			K Factor = 5.60	
B12 to 206	0.0	0.874 150.0 0.1301	2O 1N	6.0 7.0 0.0	7.083 13.000 20.083	19.508 0.0 2.612			Vel = 8.27	
	0.0 15.46					22.120			K Factor = 3.29	
S13 to B13	15.26	0.874 150.0 0.1270	1O	3.0 0.0 0.0	20.416 3.000 23.416	7.426 8.842 2.974			K Factor = 5.60	
B13 to 203	0.0	0.874 150.0 0.1270	2N 1O	14.0 3.0 0.0	7.167 17.000 24.167	19.242 0.0 3.070			Vel = 8.16	
	0.0 15.26					22.312			K Factor = 3.23	
200 to 200A	-32.24	1.598 150.0 -0.0268	1N	9.0 0.0 0.0	32.583 9.000 41.583	32.585 0.0 -1.116			Vel = 5.16	
200A to 201	0.0	1.394 150.0 -0.0521	1N	8.0 0.0 0.0	117.333 8.000 125.333	31.469 0.0 -6.536			Vel = 6.78	
201 to 202	0.0	1.394 150.0 -0.0523		0.0 0.0 0.0	2.083 0.0 2.083	24.933 0.0 -0.109			Vel = 6.78	
202 to 203	0.0	1.394 150.0 -0.0522	1N	8.0 0.0 0.0	40.167 8.000 48.167	24.824 0.0 -2.512			Vel = 6.78	
203 to 204	15.26	1.394 150.0 -0.0159		0.0 0.0 0.0	29.167 0.0 29.167	22.312 0.0 -0.465			Vel = 3.57	
204 to 205	16.20	1.394 150.0 -0.0001	2N	16.0 0.0 0.0	37.417 16.000 53.417	21.847 0.0 -0.003			Vel = 0.16	
205 to 206	14.81	1.394 150.0 0.0112		0.0 0.0 0.0	24.583 0.0 24.583	21.844 0.0 0.276			Vel = 2.95	
206 to 206A	15.46	1.394 150.0 0.0442	6N	48.0 0.0 0.0	150.583 48.000 198.583	22.120 0.0 8.783			Vel = 6.20	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
206A to 200	0.0 29.49	1.598 150.0 0.0228	2N 1O	18.0 8.0 0.0	47.917 26.000 73.917	30.903 0.0 1.682				
	0.0 29.49						32.585		Vel = 4.72	
200 to 2ND	61.73	2.157 120.0 0.0313	4E 1Ball 1S	24.613 2.769 13.537	33.000 40.919 73.919	32.585 0.0 2.311				
									Vel = 5.42	
2ND to SP1A	0.0 61.73	2.003 150.0 0.0297	1N 1O	11.0 10.0 0.0	30.333 21.000 51.333	34.896 -0.288 1.524				
	0.0 61.73						36.132		Vel = 6.29	
									K Factor = 10.27	
SP1 to SP1A	0.0	6.357 120.0 0.0	1T	37.72 0.0 0.0	1.917 37.720 39.637	36.132 0.0 0.0				
									Vel = 0	
SP1A to SP2	61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	36.132 0.0 0.018				
									Vel = 0.62	
SP2 to SP3	0.0 61.73	6.357 120.0 0.0001	1E	17.603 0.0 0.0	16.917 17.603 34.520	36.150 0.0 0.005				
									Vel = 0.62	
SP3 to SP3A	0.0 61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	77.250 37.720 114.970	36.155 0.0 0.019				
									Vel = 0.62	
SP3A to SP4	0.0 61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	2.000 37.720 39.720	36.174 0.0 0.006				
									Vel = 0.62	
SP4 to SP4X	0.0 61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	128.083 37.720 165.803	36.180 0.0 0.027				
									Vel = 0.62	
SP4X to SP5	0.0 61.73	6.357 120.0 0.0002	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	36.207 0.0 0.029				
									Vel = 0.62	
SP5 to SP6	0.0 61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	36.236 0.0 0.018				
									Vel = 0.62	
SP6 to SP7	0.0 61.73	6.357 120.0 0.0001	2E	35.205 0.0 0.0	25.417 35.205 60.622	36.254 0.0 0.009				
									Vel = 0.62	
SP7 to SP8	0.0 61.73	6.357 120.0 0.0001	1E	17.603 0.0 0.0	10.583 17.603 28.186	36.263 4.584 0.004				
									Vel = 0.62	
SP8 to TOS	0.0 61.73	6.357 120.0 0.0002	1E	17.603 0.0 0.0	11.833 17.603 29.436	40.851 0.0 0.005				
									Vel = 0.62	
TOS to BOS	0.0 61.73	6.357 120.0 0.0002	1T	37.72 0.0 0.0	5.250 37.720 42.970	40.856 2.274 0.007				
									Vel = 0.62	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BOS to FLG	0.0 61.73	3.26 140.0 0.0032	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	43.137 8.785 0.013			* * Fixed Loss = 7.053 Vel = 2.37	
FLG to CH1	0.0 61.73	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	51.935 2.599 0.001			Vel = 0.37	
CH1 to UG1	0.0 61.73	7.68 150.0 0.0	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	54.535 0.0 0.005			Vel = 0.43	
	0.0 61.73					54.540			K Factor = 8.36	
UG1 to UG2	-931.65 -931.65	7.68 150.0 -0.0065	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	54.540 0.0 -7.234			Qa = 150 Vel = 6.45	
UG2 to UG3	0.0 -931.65	7.68 150.0 -0.0065	1T	43.857 0.0 0.0	312.417 43.857 356.274	47.306 0.0 -2.305			Vel = 6.45	
UG3 to CT1	0.0 -931.65	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	45.001 8.280 -0.498			* * Fixed Loss = 8.28 Vel = 6.45	
CT1 to CT2	0.0 -931.65	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	52.783 0.0 -0.538			Vel = 3.03	
CT2 to CT3	-211.73 -1143.38	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	52.245 0.0 -0.503			Vel = 3.72	
CT3 to UG1	0.0 -1143.38	5.86 150.0 -0.0353	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	51.742 11.248 -8.450			* * Fixed Loss = 11.248 Vel = 13.60	
	0.0 -1143.38					54.540			K Factor = -154.82	
CT2 to CTY	211.73 211.73	6.16 140.0 0.0014	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	52.245 -3.248 0.124			Vel = 2.28	
	0.0 211.73					49.121			K Factor = 30.21	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section A Low Pressure Dry System Remote 3.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 16.674
D2 - System Flow : 64.625
D2 - System Pressure : 70.591
Hose (Demand) : 150
D3 - System Demand : 214.625
Safety Margin : 19.124



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'El Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S30	41.0	4.9	8.2	na	14.03	0.05	256	8.2
T31	41.417		10.18	na				
S31	41.0	4.9	9.92	na	15.43	0.05	256	8.2
S32	41.0	4.9	12.93	na	17.62	0.05	256	8.2
S33	41.0	4.9	12.81	na	17.54	0.05	256	8.2
400	41.417		33.7	na				
401	41.417		14.98	na				
402	41.417		14.84	na				
403	41.417		14.97	na				
TOD1	41.417		40.62	na				
BOD1	35.917		45.34	na				
DPVF	20.833		54.57	na				
SP2	20.833		57.6	na				
SP3	20.833		57.61	na				
SP3A	20.833		57.62	na				
SP4	20.833		57.63	na				
SP5	20.833		57.69	na				
SP6	20.833		57.71	na				
SP7	20.833		57.71	na				
SP8	10.25		62.3	na				
TOS	10.25		62.31	na				
BOS	5.0		64.59	na				
FLG	1.0		73.38	na				
CH1	-5.0		75.98	na				
UG1	-5.0		75.99	na	150.0			
UG2	-5.0		68.77	na				
UG3	-5.0		66.47	na				
CT1	-5.0		74.25	na				
CT2	-5.0		73.71	na				
CT3	-5.0		73.21	na				
CTY	2.5		70.59	na				

The maximum velocity is 15.76 and it occurs in the pipe between nodes T31 and 401

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S30 to T31	14.03	0.874 150.0	1N 1O	7.0 3.0 0.0	9.917 10.000 19.917	8.200 -0.181 2.166			K Factor = 4.90	
T31 to 401	15.44	0.874 150.0	1O	3.0 0.0 0.0	8.167 3.000 11.167	10.185 0.0 4.791			Vel = 7.50	
	29.47	0.4290							Vel = 15.76	
	0.0 29.47					14.976			K Factor = 7.62	
S31 to T31	15.43	0.874 150.0	1O	3.0 0.0 0.0	0.417 3.000 3.417	9.922 -0.181 0.444			K Factor = 4.90	
	0.0 15.43	0.1299							Vel = 8.25	
						10.185			K Factor = 4.83	
S32 to 403	17.62	0.874 150.0	1N 1O	7.0 3.0 0.0	3.417 10.000 13.417	12.931 -0.181 2.223			K Factor = 4.90	
	0.0 17.62	0.1657							Vel = 9.42	
						14.973			K Factor = 4.55	
S33 to 402	17.54	0.874 150.0	1N 1O	7.0 3.0 0.0	3.417 10.000 13.417	12.812 -0.181 2.205			K Factor = 4.90	
	0.0 17.54	0.1643							Vel = 9.38	
						14.836			K Factor = 4.55	
400 to 401	-36.92	1.394 120.0	4N	32.0 0.0 0.0	152.917 32.000 184.917	33.700 0.0 -18.724				
	-36.92	-0.1013							Vel = 7.76	
401 to 402	29.47	1.394 120.0	1N	8.0 0.0 0.0	18.750 8.000 26.750	14.976 0.0 -0.140				
	-7.45	-0.0052							Vel = 1.57	
402 to 403	17.54	1.394 120.0		0.0 0.0 0.0	15.000 0.0 15.000	14.836 0.0 0.137				
	10.09	0.0091							Vel = 2.12	
403 to 400	17.62	1.394 120.0	2N 1O	16.0 6.0 0.0	292.417 22.000 314.417	14.973 0.0 18.727				
	27.71	0.0596							Vel = 5.83	
	0.0 27.71					33.700			K Factor = 4.77	
400 to TOD1	64.63	1.394 150.0	2N	16.0 0.0 0.0	20.667 16.000 36.667	33.700 0.0 6.924				
	64.63	0.1888							Vel = 13.59	
TOD1 to BOD1	0.0	1.61 120.0	1Dvc 1T	3.0 8.0 0.0	5.500 11.000 16.500	40.624 2.382 2.334				
	64.63	0.1415							Vel = 10.19	
BOD1 to DPVF	0.0	1.61 120.0	1E	4.0 0.0 0.0	15.084 4.000 19.084	45.340 6.533 2.700				
	64.63	0.1415							Vel = 10.19	
DPVF to SP2	0.0	1.61 120.0	1T	8.0 0.0 0.0	13.417 8.000 21.417	54.573 0.0 3.029				
	64.63	0.1414							Vel = 10.19	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 64.63					57.602			K Factor = 8.52	
SP2 to SP3	64.63	6.357 120.0 0.0002	1E	17.603 0.0 0.0	16.917 17.603 34.520	57.602 0.0 0.006			Vel = 0.65	
SP3 to SP3A	0.0 64.63	6.357 120.0 0.0002		0.0 0.0 0.0	75.250 0.0 75.250	57.608 0.0 0.014			Vel = 0.65	
SP3A to SP4	0.0 64.63	6.357 120.0 0.0002	1T	37.72 0.0 0.0	1.917 37.720 39.637	57.622 0.0 0.007			Vel = 0.65	
SP4 to SP5	0.0 64.63	6.357 120.0 0.0002	2E 1F	35.205 8.801 37.72	260.500 81.726 342.226	57.629 0.0 0.060			Vel = 0.65	
SP5 to SP6	0.0 64.63	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	57.689 0.0 0.019			Vel = 0.65	
SP6 to SP7	0.0 64.63	6.357 120.0 0.0002	1E	17.603 0.0 0.0	16.167 17.603 33.770	57.708 0.0 0.006			Vel = 0.65	
SP7 to SP8	0.0 64.63	6.357 120.0 0.0002	1E	17.603 0.0 0.0	10.583 17.603 28.186	57.714 4.584 0.005			Vel = 0.65	
SP8 to TOS	0.0 64.63	6.357 120.0 0.0002	2E	35.205 0.0 0.0	5.917 35.205 41.122	62.303 0.0 0.007			Vel = 0.65	
TOS to BOS	0.0 64.63	6.357 120.0 0.0002	1T	37.72 0.0 0.0	5.250 37.720 42.970	62.310 2.274 0.007			Vel = 0.65	
BOS to FLG	0.0 64.63	3.26 140.0 0.0035	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	64.591 8.777 0.014			** Fixed Loss = 7.044 Vel = 2.48	
FLG to CH1	0.0 64.63	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	73.382 2.599 0.001			Vel = 0.39	
CH1 to UG1	0.0 64.63	7.68 150.0 0.0	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	75.982 0.0 0.005			Vel = 0.45	
	0.0 64.63					75.987			K Factor = 7.41	
UG1 to UG2	-930.79	7.68 150.0 -0.0065	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	75.987 0.0 -7.221			Qa = 150 Vel = 6.45	
UG2 to UG3	0.0 -930.79	7.68 150.0 -0.0065	1T	43.857 0.0 0.0	312.417 43.857 356.274	68.766 0.0 -2.301			Vel = 6.45	
UG3 to CT1	0.0 -930.79	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	66.465 8.281 -0.497			** Fixed Loss = 8.281 Vel = 6.45	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CT1 to CT2	0.0 -930.79	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	74.249 0.0 -0.537			Vel = 3.03	
CT2 to CT3	-214.63 -1145.42	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	73.712 0.0 -0.505			Vel = 3.73	
CT3 to UG1	0.0 -1145.42	5.86 150.0 -0.0354	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	73.207 11.258 -8.478			* * Fixed Loss = 11.258 Vel = 13.63	
	0.0 -1145.42					75.987			K Factor = -131.40	
CT2 to CTY	214.62 214.62	6.16 140.0 0.0014	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	73.712 -3.248 0.127			Vel = 2.31	
	0.0 214.62					70.591			K Factor = 25.54	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section A Low Pressure Dry System Remote 4.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 2.851
D2 - System Flow : 37.355
D2 - System Pressure : 39.725
Hose (Demand) : 150
D3 - System Demand : 187.355
Safety Margin : 50.054



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S40	9.083	5.6	9.99	na	17.7	0.15	118	7.0
T41	9.5		12.83	na				
S41	9.083	5.6	12.32	na	19.65	0.15	118	7.0
S50	9.083		20.76	na				
S51	9.083		20.76	na				
S52	9.083		21.04	na				
S53	9.083		21.04	na				
S54	9.083		21.35	na				
100	9.5		15.05	na				
101	9.5		20.58	na				
102	9.5		20.86	na				
103	9.5		21.17	na				
TOD3	9.5		29.83	na				
BOD3	4.0		32.72	na				
DF3	4.0		32.83	na				
DPVF	20.833		26.96	na				
SP2	20.833		27.31	na				
SP3	20.833		27.31	na				
SP3A	20.833		27.32	na				
SP4	20.833		27.32	na				
SP4X	20.833		27.33	na				
SP5	20.833		27.34	na				
SP6	20.833		27.35	na				
SP7	20.833		27.36	na				
SP8	10.25		31.94	na				
TOS	10.25		31.94	na				
BOS	5.0		34.22	na				
FLG	1.0		42.68	na				
CH1	-5.0		45.28	na				
UG1	-5.0		45.28	na	150.0			
UG2	-5.0		37.98	na				
UG3	-5.0		35.65	na				
CT1	-5.0		43.42	na				
CT2	-5.0		42.87	na				
CT3	-5.0		42.39	na				
CTY	2.5		39.72	na				

The maximum velocity is 19.97 and it occurs in the pipe between nodes T41 and 100

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S40 to T41	17.70 17.7	0.874 150.0 0.1671	1N	7.0 0.0 0.0	11.084 7.000 18.084	9.990 -0.181 3.022			K Factor = 5.60	
T41 to 100	19.65 37.35	0.874 150.0 0.6655	1O	3.0 0.0 0.0	0.333 3.000 3.333	12.831 0.0 2.218			Vel = 9.47	
	0.0 37.35					15.049			K Factor = 9.63	
S41 to T41	19.65 19.65	0.874 150.0 0.2028	1O	3.0 0.0 0.0	0.417 3.000 3.417	12.319 -0.181 0.693			K Factor = 5.60	
	0.0 19.65					12.831			Vel = 10.51	
S50 to 101	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	2.667 10.000 12.667	20.759 -0.181 0.0			K Factor = 5.49	
	0.0 0.0					20.578			Vel = 0	
S51 to 101	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	11.500 10.000 21.500	20.759 -0.181 0.0			K Factor = 0	
	0.0 0.0					20.578			Vel = 0	
S52 to 102	0.0	0.874 150.0 0.0	2O	6.0 0.0 0.0	0.417 6.000 6.417	21.038 -0.181 0.0			K Factor = 0	
	0.0 0.0					20.857			Vel = 0	
S53 to 102	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	11.500 10.000 21.500	21.038 -0.181 0.0			K Factor = 0	
	0.0 0.0					20.857			Vel = 0	
S54 to 103	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	6.917 10.000 16.917	21.352 -0.181 0.0			K Factor = 0	
	0.0 0.0					21.171			Vel = 0	
100 to 101	37.35	1.598 150.0 0.0352	4N	36.0 0.0 0.0	121.000 36.000 157.000	15.049 0.0 5.529			K Factor = 0	
101 to 102	0.0	1.598 150.0 0.0352		0.0 0.0 0.0	7.917 0.0 7.917	20.578 0.0 0.279			Vel = 5.97	
102 to 103	0.0	1.598 150.0 0.0352		0.0 0.0 0.0	8.917 0.0 8.917	20.857 0.0 0.314			Vel = 5.97	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
103 to TOD3	0.0 37.35	1.598 150.0 0.0352	6N	54.0 0.0 0.0	191.833 54.000 245.833	21.171 0.0 8.659			Vel = 5.97	
TOD3 to BOD3	0.0 37.35	1.682 120.0 0.0414	1Dvc 1Ball	3.712 3.094 0.0	5.500 6.806 12.306	29.830 2.382 0.510			Vel = 5.39	
BOD3 to DF3	0.0 37.35	1.61 100.0 0.0720		0.0 0.0 0.0	1.500 0.0 1.500	32.722 0.0 0.108			Vel = 5.89	
DF3 to DPVF	0.0 37.35	1.61 100.0 0.0719	1E	2.855 0.0 0.0	16.833 2.855 19.688	32.830 -7.290 1.415			Vel = 5.89	
DPVF to SP2	0.0 37.35	2.067 120.0 0.0152	1T	10.0 0.0 0.0	13.417 10.000 23.417	26.955 0.0 0.356			Vel = 3.57	
	0.0 37.35					27.311			K Factor = 7.15	
SP2 to SP3	37.35 37.35	6.357 120.0 0.0001	1E	17.603 0.0 0.0	16.917 17.603 34.520	27.311 0.0 0.002			Vel = 0.38	
SP3 to SP3A	0.0 37.35	6.357 120.0 0.0001	1T	37.72 0.0 0.0	77.250 37.720 114.970	27.313 0.0 0.008			Vel = 0.38	
SP3A to SP4	0.0 37.35	6.357 120.0 0.0001	1T	37.72 0.0 0.0	2.000 37.720 39.720	27.321 0.0 0.002			Vel = 0.38	
SP4 to SP4X	0.0 37.35	6.357 120.0 0.0001	1T	37.72 0.0 0.0	128.083 37.720 165.803	27.323 0.0 0.011			Vel = 0.38	
SP4X to SP5	0.0 37.35	6.357 120.0 0.0001	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	27.334 0.0 0.011			Vel = 0.38	
SP5 to SP6	0.0 37.35	6.357 120.0 0.0001	1T	37.72 0.0 0.0	71.750 37.720 109.470	27.345 0.0 0.007			Vel = 0.38	
SP6 to SP7	0.0 37.35	6.357 120.0 0.0001	2E	35.205 0.0 0.0	25.417 35.205 60.622	27.352 0.0 0.004			Vel = 0.38	
SP7 to SP8	0.0 37.35	6.357 120.0 0.0	1E	17.603 0.0 0.0	10.583 17.603 28.186	27.356 4.584 0.001			Vel = 0.38	
SP8 to TOS	0.0 37.35	6.357 120.0 0.0001	1E	17.603 0.0 0.0	11.833 17.603 29.436	31.941 0.0 0.002			Vel = 0.38	
TOS to BOS	0.0 37.35	6.357 120.0 0.0001	1T	37.72 0.0 0.0	5.250 37.720 42.970	31.943 2.274 0.003			Vel = 0.38	
BOS to FLG	0.0 37.35	3.26 140.0 0.0012	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	34.220 8.459 0.005			* * Fixed Loss = 6.727 Vel = 1.44	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
FLG to CH1	0.0 37.35	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	42.684 2.599 0.0				
								Vel =	0.22	
CH1 to UG1	0.0 37.35	7.68 150.0 0.0	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	45.283 0.0 0.002				
								Vel =	0.26	
	0.0 37.35					45.285		K Factor =	5.55	
UG1 to UG2	-936.76 -936.76	7.68 150.0 -0.0065	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	45.285 0.0 -7.308		Qa =	150	
								Vel =	6.49	
UG2 to UG3	0.0 -936.76	7.68 150.0 -0.0065	1T	43.857 0.0 0.0	312.417 43.857 356.274	37.977 0.0 -2.327				
								Vel =	6.49	
UG3 to CT1	0.0 -936.76	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	35.650 8.271 -0.504		* * Fixed Loss =	8.271	
								Vel =	6.49	
CT1 to CT2	0.0 -936.76	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	43.417 0.0 -0.544				
								Vel =	3.05	
CT2 to CT3	-187.35 -1124.11	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	42.873 0.0 -0.487				
								Vel =	3.66	
CT3 to UG1	0.0 -1124.11	5.86 150.0 -0.0342	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	42.386 11.087 -8.188		* * Fixed Loss =	11.087	
								Vel =	13.37	
	0.0 -1124.11					45.285		K Factor =	-167.04	
CT2 to CTY	187.36 187.36	6.16 140.0 0.0011	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	42.873 -3.248 0.100				
								Vel =	2.02	
	0.0 187.36					39.725		K Factor =	29.73	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section A Low Pressure Dry System Remote 5.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 2.851
D2 - System Flow : 92.395
D2 - System Pressure : 81.439
Hose (Demand) : 150
D3 - System Demand : 242.395
Safety Margin : 8.205



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S40	9.083		13.32	na				
T41	9.5		13.14	na				
S41	9.083		13.32	na				
S50	9.083	5.6	11.01	na	18.58	0.15	105	7.0
S51	9.083	5.6	9.79	na	17.53	0.15	105	7.0
S52	9.083	5.6	12.28	na	19.63	0.15	105	7.0
S53	9.083	5.6	9.99	na	17.7	0.15	118	7.0
S54	9.083	5.6	11.47	na	18.96	0.15	123	7.0
100	9.5		13.14	na				
101	9.5		13.14	na				
102	9.5		13.4	na				
103	9.5		14.5	na				
TOD3	9.5		60.74	na				
BOD3	4.0		65.85	na				
DF3	4.0		66.42	na				
DPVF	20.833		66.69	na				
SP2	20.833		68.6	na				
SP3	20.833		68.61	na				
SP3A	20.833		68.65	na				
SP4	20.833		68.66	na				
SP4X	20.833		68.72	na				
SP5	20.833		68.78	na				
SP6	20.833		68.81	na				
SP7	20.833		68.83	na				
SP8	10.25		73.43	na				
TOS	10.25		73.44	na				
BOS	5.0		75.73	na				
FLG	1.0		84.05	na				
CH1	-5.0		86.66	na				
UG1	-5.0		86.67	na	150.0			
UG2	-5.0		79.53	na				
UG3	-5.0		77.26	na				
CT1	-5.0		85.06	na				
CT2	-5.0		84.53	na				
CT3	-5.0		84.0	na				
CTY	2.5		81.44	na				

The maximum velocity is 14.78 and it occurs in the pipe between nodes 103 and TOD3

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S40 to T41	0.0 0.0	0.874 150.0 0.0	1N	7.0 0.0 0.0	11.084 7.000 18.084	13.321 -0.181 0.0			Vel = 0	
T41 to 100	0.0 0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	0.333 3.000 3.333	13.140 0.0 0.0			Vel = 0	
	0.0 0.0					13.140			K Factor = 0	
S41 to T41	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	0.417 3.000 3.417	13.321 -0.181 0.0			Vel = 0	
	0.0 0.0					13.140			K Factor = 0	
S50 to 101	18.58 18.58	0.874 150.0 0.1828	1N 1O	7.0 3.0 0.0	2.667 10.000 12.667	11.006 -0.181 2.315			K Factor = 5.60 Vel = 9.94	
	0.0 18.58					13.140			K Factor = 5.13	
S51 to 101	17.53 17.53	0.874 150.0 0.1640	1N 1O	7.0 3.0 0.0	11.500 10.000 21.500	9.794 -0.181 3.527			K Factor = 5.60 Vel = 9.37	
	0.0 17.53					13.140			K Factor = 4.84	
S52 to 102	19.63 19.63	0.874 150.0 0.2024	2O	6.0 0.0 0.0	0.417 6.000 6.417	12.284 -0.181 1.299			K Factor = 5.60 Vel = 10.50	
	0.0 19.63					13.402			K Factor = 5.36	
S53 to 102	17.70 17.7	0.874 150.0 0.1671	1N 1O	7.0 3.0 0.0	11.500 10.000 21.500	9.990 -0.181 3.593			K Factor = 5.60 Vel = 9.47	
	0.0 17.70					13.402			K Factor = 4.83	
S54 to 103	18.96 18.96	0.874 150.0 0.1899	1N 1O	7.0 3.0 0.0	6.917 10.000 16.917	11.468 -0.181 3.212			K Factor = 5.60 Vel = 10.14	
	0.0 18.96					14.499			K Factor = 4.98	
100 to 101	0.0 0.0	1.598 150.0 0.0	4N	36.0 0.0 0.0	121.000 36.000 157.000	13.140 0.0 0.0			Vel = 0	
101 to 102	36.10 36.1	1.598 150.0 0.0331		0.0 0.0 0.0	7.917 0.0 7.917	13.140 0.0 0.262			Vel = 5.77	
102 to 103	37.33 73.43	1.598 150.0 0.1230		0.0 0.0 0.0	8.917 0.0 8.917	13.402 0.0 1.097			Vel = 11.75	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
103 to TOD3	18.96 92.39	1.598 150.0 0.1881	6N	54.0 0.0 0.0	191.833 54.000 245.833	14.499 0.0 46.242			Vel = 14.78	
TOD3 to BOD3	0.0 92.39	1.682 120.0 0.2214	1Dvc 1Ball	3.712 3.094 0.0	5.500 6.806 12.306	60.741 2.382 2.725			Vel = 13.34	
BOD3 to DF3	0.0 92.39	1.61 100.0 0.3840		0.0 0.0 0.0	1.500 0.0 1.500	65.848 0.0 0.576			Vel = 14.56	
DF3 to DPVF	0.0 92.39	1.61 100.0 0.3840	1E	2.855 0.0 0.0	16.833 2.855 19.688	66.424 -7.290 7.560			Vel = 14.56	
DPVF to SP2	0.0 92.39	2.067 120.0 0.0812	1T	10.0 0.0 0.0	13.417 10.000 23.417	66.694 0.0 1.901			Vel = 8.83	
	0.0 92.39					68.595			K Factor = 11.16	
SP2 to SP3	92.39 92.39	6.357 120.0 0.0003	1E	17.603 0.0 0.0	16.917 17.603 34.520	68.595 0.0 0.012			Vel = 0.93	
SP3 to SP3A	0.0 92.39	6.357 120.0 0.0003	1T	37.72 0.0 0.0	77.250 37.720 114.970	68.607 0.0 0.039			Vel = 0.93	
SP3A to SP4	0.0 92.39	6.357 120.0 0.0004	1T	37.72 0.0 0.0	2.000 37.720 39.720	68.646 0.0 0.014			Vel = 0.93	
SP4 to SP4X	0.0 92.39	6.357 120.0 0.0003	1T	37.72 0.0 0.0	128.083 37.720 165.803	68.660 0.0 0.056			Vel = 0.93	
SP4X to SP5	0.0 92.39	6.357 120.0 0.0003	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	68.716 0.0 0.060			Vel = 0.93	
SP5 to SP6	0.0 92.39	6.357 120.0 0.0003	1T	37.72 0.0 0.0	71.750 37.720 109.470	68.776 0.0 0.038			Vel = 0.93	
SP6 to SP7	0.0 92.39	6.357 120.0 0.0003	2E	35.205 0.0 0.0	25.417 35.205 60.622	68.814 0.0 0.020			Vel = 0.93	
SP7 to SP8	0.0 92.39	6.357 120.0 0.0004	1E	17.603 0.0 0.0	10.583 17.603 28.186	68.834 4.584 0.010			Vel = 0.93	
SP8 to TOS	0.0 92.39	6.357 120.0 0.0003	1E	17.603 0.0 0.0	11.833 17.603 29.436	73.428 0.0 0.010			Vel = 0.93	
TOS to BOS	0.0 92.39	6.357 120.0 0.0003	1T	37.72 0.0 0.0	5.250 37.720 42.970	73.438 2.274 0.014			Vel = 0.93	
BOS to FLG	0.0 92.39	3.26 140.0 0.0068	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	75.726 8.301 0.027			* * Fixed Loss = 6.569 Vel = 3.55	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
FLG to CH1	0.0 92.39	8.27 140.0 0.0001	1E	28.468 0.0 0.0	11.000 28.468 39.468	84.054 2.599 0.003				
								Vel =	0.55	
CH1 to UG1	0.0 92.39	7.68 150.0 0.0001	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	86.656 0.0 0.010				
								Vel =	0.64	
	0.0 92.39					86.666		K Factor =	9.92	
UG1 to UG2	-924.80 -924.8	7.68 150.0 -0.0064	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	86.666 0.0 -7.136		Qa =	150	
								Vel =	6.40	
UG2 to UG3	0.0 -924.8	7.68 150.0 -0.0064	1T	43.857 0.0 0.0	312.417 43.857 356.274	79.530 0.0 -2.273				
								Vel =	6.40	
UG3 to CT1	0.0 -924.8	7.68 150.0 -0.0064	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	77.257 8.292 -0.491		* * Fixed Loss =	8.292	
								Vel =	6.40	
CT1 to CT2	0.0 -924.8	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	85.058 0.0 -0.531				
								Vel =	3.01	
CT2 to CT3	-242.39 -1167.19	11.2 150.0 -0.0016	1T	66.446 0.0 0.0	267.583 66.446 334.029	84.527 0.0 -0.522				
								Vel =	3.80	
CT3 to UG1	0.0 -1167.19	5.86 150.0 -0.0366	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	84.005 11.440 -8.779		* * Fixed Loss =	11.44	
								Vel =	13.88	
	0.0 -1167.19					86.666		K Factor =	-125.38	
CT2 to CTY	242.40 242.4	6.16 140.0 0.0018	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	84.527 -3.248 0.160				
								Vel =	2.61	
	0.0 242.40					81.439		K Factor =	26.86	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section B Wet System Remote 6.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 16.494
D2 - System Flow : 61.326
D2 - System Pressure : 48.091
Hose (Demand) : 150
D3 - System Demand : 211.326
Safety Margin : 41.632



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S70	41.0		26.41	na				
S71	41.0		26.41	na				
400	41.417		26.23	na				
401	41.417		26.23	na				
402	41.417		26.23	na				
TOD2	41.417		26.23	na				
BOD2	35.917		28.61	na				
BOD1	35.917		28.61	na				
DPVF	20.833		35.14	na				
S72	40.583		12.99	na				
B72	30.75		17.25	na				
B76	30.75		17.25	na				
S73	41.0		12.4	na				
B73	30.75		16.84	na				
S74	40.583		12.74	na				
T74	40.583		12.74	na				
B74	30.75		16.99	na				
S75	40.583		12.74	na				
S76	40.583		12.99	na				
S77	40.583		12.79	na				
T77	40.583		12.79	na				
B77	30.75		17.05	na				
S78	40.583		12.79	na				
S79	40.583		12.79	na				
B79	30.75		17.05	na				
S60	40.583	5.6	7.0	na	14.82	0.1	91	7.0
B60	30.75		12.8	na				
S61	40.583	5.6	7.67	na	15.51	0.1	91	7.0
B61	30.75		13.61	na				
S62	40.583	5.6	7.55	na	15.39	0.1	91	7.0
B62	30.75		13.47	na				
S63	40.583	5.6	7.77	na	15.61	0.1	89	7.0
B63	30.75		13.73	na				
300	30.75		22.49	na				
301	30.75		16.93	na				
302	30.75		16.8	na				
303	30.75		16.84	na				
304	30.75		16.84	na				
305	30.75		16.99	na				
306	30.75		17.05	na				
307	30.75		17.25	na				
3RD	30.75		29.23	na				
2ND	20.833		35.06	na				
SP2	20.833		35.14	na				
SP3	20.833		35.14	na				
SP3A	20.833		35.14	na				
SP4	20.833		35.15	na				
SP5	20.833		35.2	na				
SP6	20.833		35.22	na				
SP7	20.833		35.23	na				
SP8	10.25		39.81	na				
TOS	10.25		39.82	na				
BOS	5.0		42.1	na				
FLG	1.0		50.9	na				
CH1	-5.0		53.5	na				
UG1	-5.0		53.51	na	150.0			
UG2	-5.0		46.27	na				
UG3	-5.0		43.97	na				
CT1	-5.0		51.75	na				
CT2	-5.0		51.21	na				
CT3	-5.0		50.71	na				
CTY	2.5		48.09	na				

Flow Summary - Standard

Ranger Fire Inc
Summit Square III

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
----------	-----------	--------	-----------	----	-------------	---------	------	------------

The maximum velocity is 13.6 and it occurs in the pipe between nodes CT3 and UG1

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S70 to 401	0.0 0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	3.667 10.000 13.667	26.408 -0.181 0.0			Vel = 0	
	0.0 0.0					26.227			K Factor = 0	
S71 to 401	0.0 0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	3.667 10.000 13.667	26.408 -0.181 0.0			Vel = 0	
	0.0 0.0					26.227			K Factor = 0	
400 to 401	0.0 0.0 0.0	1.394 150.0 0.0	1N	8.0 0.0 0.0	131.000 8.000 139.000	26.227 0.0 0.0			Vel = 0	
401 to 402	0.0 0.0 0.0	1.394 150.0 0.0	3N	24.0 0.0 0.0	146.167 24.000 170.167	26.227 0.0 0.0			Vel = 0	
402 to 400	0.0 0.0 0.0	1.394 150.0 0.0	1O	6.0 0.0 0.0	13.333 6.000 19.333	26.227 0.0 0.0			Vel = 0	
	0.0 0.0					26.227			K Factor = 0	
400 to TOD2	0.0 0.0 0.0	1.394 150.0 0.0	1N	8.0 0.0 0.0	81.500 8.000 89.500	26.227 0.0 0.0			Vel = 0	
TOD2 to BOD2	0.0 0.0 0.0	1.61 120.0 0.0	1E 1Dvc	4.0 3.0 0.0	5.500 7.000 12.500	26.227 2.382 0.0			Vel = 0	
BOD2 to BOD1	0.0 0.0 0.0	1.61 120.0 0.0	1T	8.0 0.0 0.0	2.000 8.000 10.000	28.609 0.0 0.0			Vel = 0	
BOD1 to DPVF	0.0 0.0 0.0	1.61 120.0 0.0	1E	4.0 0.0 0.0	15.084 4.000 19.084	28.609 6.533 0.0			Vel = 0	
DPVF to SP2	0.0 0.0 0.0	1.61 120.0 0.0	1T	8.0 0.0 0.0	13.417 8.000 21.417	35.142 0.0 0.0			Vel = 0	
	0.0 0.0					35.142			K Factor = 0	
S72 to B72	0.0 0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	9.833 3.000 12.833	12.990 4.259 0.0			Vel = 0	
B72 to B76	0.0 0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	8.750 3.000 11.750	17.249 0.0 0.0			Vel = 0	
B76 to 307	0.0 0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	7.167 3.000 10.167	17.249 0.0 0.0			Vel = 0	
	0.0									

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0					17.249			K Factor = 0	
S73 to B73	0.0	0.874 150.0	3N 1O	21.0 3.0	16.000 24.000	12.401 4.439				
	0.0	0.0		0.0	40.000	0.0			Vel = 0	
B73 to 303	0.0	0.874 150.0	1N 1O	7.0 3.0	4.167 10.000	16.840 0.0				
	0.0	0.0		0.0	14.167	0.0			Vel = 0	
	0.0					16.840			K Factor = 0	
S74 to T74	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	12.736 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
T74 to B74	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	12.736 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	
B74 to 305	0.0	0.874 150.0	1O	3.0 0.0	6.000 3.000	16.995 0.0				
	0.0	0.0		0.0	9.000	0.0			Vel = 0	
	0.0					16.995			K Factor = 0	
S75 to T74	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	12.736 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
	0.0					12.736			K Factor = 0	
S76 to B76	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	12.990 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	
	0.0					17.249			K Factor = 0	
S77 to T77	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	12.792 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
T77 to B77	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	12.792 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	
B77 to 306	0.0	0.874 150.0	1N 1O	7.0 3.0	3.333 10.000	17.051 0.0				
	0.0	0.0		0.0	13.333	0.0			Vel = 0	
	0.0					17.051			K Factor = 0	
S78 to T77	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	12.792 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
	0.0					12.792			K Factor = 0	
S79 to B79	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	12.792 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
B79 to 306	0.0 0.0 0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	6.250 10.000 16.250	17.051 0.0 0.0				Vel = 0
						17.051			K Factor = 0	
S60 to B60	14.82 14.82	0.874 150.0 0.1202	1O	3.0 0.0 0.0	9.833 3.000 12.833	7.000 4.259 1.543			K Factor = 5.60	Vel = 7.93
B60 to 302A	0.0 14.82	0.874 150.0 0.1202	2N 1O	14.0 3.0 0.0	15.750 17.000 32.750	12.802 13.318 3.938				Vel = 7.93
	0.0 14.82					30.058			K Factor = 2.70	
S61 to B61	15.51 15.51	0.874 150.0 0.1308	1O	3.0 0.0 0.0	9.833 3.000 12.833	7.669 4.259 1.678			K Factor = 5.60	Vel = 8.29
B61 to 304	0.0 15.51	0.874 150.0 0.1308	2N 1O	14.0 3.0 0.0	7.750 17.000 24.750	13.606 0.0 3.238				Vel = 8.29
	0.0 15.51					16.844			K Factor = 3.78	
S62 to B62	15.39 15.39	0.874 150.0 0.1290	1O	3.0 0.0 0.0	9.833 3.000 12.833	7.555 4.259 1.655			K Factor = 5.60	Vel = 8.23
B62 to 301	0.0 15.39	0.874 150.0 0.1291	2N 1O	14.0 3.0 0.0	9.834 17.000 26.834	13.469 0.0 3.463				Vel = 8.23
	0.0 15.39					16.932			K Factor = 3.74	
S63 to B63	15.61 15.61	0.874 150.0 0.1324	1O	3.0 0.0 0.0	9.833 3.000 12.833	7.770 4.259 1.699			K Factor = 5.60	Vel = 8.35
B63 to 307	0.0 15.61	0.874 150.0 0.1324	2N 1O	14.0 3.0 0.0	9.584 17.000 26.584	13.728 0.0 3.521				Vel = 8.35
	0.0 15.61					17.249			K Factor = 3.76	
300 to 301	-25.61 -25.61	1.394 150.0 -0.0341	5N 1O	40.0 6.0 0.0	117.167 46.000 163.167	22.491 0.0 -5.559				Vel = 5.38
301 to 302	15.39 -10.22	1.394 150.0 -0.0062	1O	6.0 0.0 0.0	15.833 6.000 21.833	16.932 0.0 -0.136				Vel = 2.15
302 to 303	14.82 4.6	1.394 150.0 0.0014	1N	8.0 0.0 0.0	23.333 8.000 31.333	16.796 0.0 0.044				Vel = 0.97
303 to 304	0.0 4.6	1.394 150.0 0.0013		0.0 0.0 0.0	3.000 0.0 3.000	16.840 0.0 0.004				Vel = 0.97

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 8
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
304 to 305	15.50 20.1	1.394 150.0 0.0218		0.0 0.0 0.0	6.917 0.0 6.917	16.844 0.0 0.151			Vel = 4.23	
305 to 306	0.0 20.1	1.394 150.0 0.0217		0.0 0.0 0.0	2.583 0.0 2.583	16.995 0.0 0.056			Vel = 4.23	
306 to 307	0.0 20.1	1.394 150.0 0.0218		0.0 0.0 0.0	9.083 0.0 9.083	17.051 0.0 0.198			Vel = 4.23	
307 to 300	15.61 35.71	1.394 150.0 0.0630	1O	6.0 0.0 0.0	77.167 6.000 83.167	17.249 0.0 5.242			Vel = 7.51	
	0.0 35.71					22.491			K Factor = 7.53	
302 to 302A	-14.82 -14.82	1.394 150.0 -0.0124		0.0 0.0 0.0	4.500 0.0 4.500	16.796 13.318 -0.056			Vel = 3.12	
	0.0 -14.82					30.058			K Factor = -2.70	
300 to 3RD	61.33 61.33	1.682 120.0 0.1038	3E 1Ball 1S	14.849 3.094 11.137	35.833 29.080 64.913	22.491 0.0 6.735			Vel = 8.86	
3RD to 2ND	0.0 61.33	1.682 120.0 0.1038	1E	4.95 0.0 0.0	9.917 4.950 14.867	29.226 4.295 1.543			Vel = 8.86	
2ND to SP3A	0.0 61.33	4.26 120.0 0.0011	1E 1T	13.167 26.334 0.0	30.167 39.501 69.668	35.064 0.0 0.078			Vel = 1.38	
	0.0 61.33					35.142			K Factor = 10.35	
SP2 to SP3	0.0 0.0	6.357 120.0 0.0	1E	17.603 0.0 0.0	16.917 17.603 34.520	35.142 0.0 0.0			Vel = 0	
SP3 to SP3A	0.0 0.0	6.357 120.0 0.0		0.0 0.0 0.0	75.250 0.0 75.250	35.142 0.0 0.0			Vel = 0	
SP3A to SP4	61.33 61.33	6.357 120.0 0.0002	1T	37.72 0.0 0.0	1.917 37.720 39.637	35.142 0.0 0.007			Vel = 0.62	
SP4 to SP5	0.0 61.33	6.357 120.0 0.0002	2E 1F 1T	35.205 8.801 37.72	260.500 81.726 342.226	35.149 0.0 0.054			Vel = 0.62	
SP5 to SP6	0.0 61.33	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	35.203 0.0 0.018			Vel = 0.62	
SP6 to SP7	0.0 61.33	6.357 120.0 0.0001	1E	17.603 0.0 0.0	16.167 17.603 33.770	35.221 0.0 0.005			Vel = 0.62	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 9
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP7 to SP8	0.0 61.33	6.357 120.0 0.0001	1E	17.603 0.0 0.0	10.583 17.603 28.186	35.226 4.584 0.004				
								Vel =	0.62	
SP8 to TOS	0.0 61.33	6.357 120.0 0.0002	2E	35.205 0.0 0.0	5.917 35.205 41.122	39.814 0.0 0.007				
								Vel =	0.62	
TOS to BOS	0.0 61.33	6.357 120.0 0.0001	1T	37.72 0.0 0.0	5.250 37.720 42.970	39.821 2.274 0.006				
								Vel =	0.62	
BOS to FLG	0.0 61.33	3.26 140.0 0.0032	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	42.101 8.788 0.013			* * Fixed Loss = 7.056	
								Vel =	2.36	
FLG to CH1	0.0 61.33	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	50.902 2.599 0.001				
								Vel =	0.37	
CH1 to UG1	0.0 61.33	7.68 150.0 0.0	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	53.502 0.0 0.005				
								Vel =	0.42	
	0.0 61.33					53.507		K Factor =	8.38	
UG1 to UG2	-931.51 -931.51	7.68 150.0 -0.0065	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	53.507 0.0 -7.232			Qa = 150	
								Vel =	6.45	
UG2 to UG3	0.0 -931.51	7.68 150.0 -0.0065	1T	43.857 0.0 0.0	312.417 43.857 356.274	46.275 0.0 -2.304				
								Vel =	6.45	
UG3 to CT1	0.0 -931.51	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	43.971 8.280 -0.498			* * Fixed Loss = 8.28	
								Vel =	6.45	
CT1 to CT2	0.0 -931.51	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	51.753 0.0 -0.538				
								Vel =	3.03	
CT2 to CT3	-211.33 -1142.84	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	51.215 0.0 -0.502				
								Vel =	3.72	
CT3 to UG1	0.0 -1142.84	5.86 150.0 -0.0352	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	50.713 11.237 -8.443			* * Fixed Loss = 11.237	
								Vel =	13.60	
	0.0 -1142.84					53.507		K Factor =	-156.24	
CT2 to CTY	211.33 211.33	6.16 140.0 0.0014	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	51.215 -3.248 0.124				
								Vel =	2.28	
	0.0 211.33					48.091		K Factor =	30.47	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section B Low Pressure Dry System Remote 7.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 16.494
D2 - System Flow : 68.926
D2 - System Pressure : 50.437
Hose (Demand) : 150
D3 - System Demand : 218.926
Safety Margin : 39.268



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S70	41.0	4.9	14.13	na	18.42	0.05	256	8.2
S71	41.0	4.9	14.13	na	18.42	0.05	256	8.2
400	41.417		19.39	na				
401	41.417		16.4	na				
402	41.417		19.08	na				
TOD2	41.417		25.36	na				
BOD2	35.917		28.37	na				
BOD1	35.917		28.87	na				
DPVF	20.833		36.36	na				
S72	40.583		24.96	na				
B72	30.75		29.22	na				
B76	30.75		29.22	na				
S73	41.0		24.62	na				
B73	30.75		29.06	na				
S74	40.583	4.4	13.3	na	16.05	0.05	170	13.3
T74	40.583		13.74	na				
B74	30.75		24.45	na				
S75	40.583	4.4	13.3	na	16.05	0.05	170	13.3
S76	40.583		24.96	na				
S77	40.583		24.77	na				
T77	40.583		24.77	na				
B77	30.75		29.02	na				
S78	40.583		24.77	na				
S79	40.583		24.77	na				
B79	30.75		29.02	na				
S60	40.583		25.07	na				
B60	30.75		29.33	na				
S61	40.583		24.77	na				
B61	30.75		29.03	na				
S62	40.583		25.27	na				
B62	30.75		29.53	na				
S63	40.583		24.96	na				
B63	30.75		29.22	na				
300	30.75		30.97	na				
301	30.75		29.53	na				
302	30.75		29.33	na				
303	30.75		29.06	na				
304	30.75		29.03	na				
305	30.75		28.97	na				
306	30.75		29.02	na				
307	30.75		29.22	na				
3RD	30.75		32.65	na				
2ND	20.833		37.41	na				
SP2	20.833		37.43	na				
SP3	20.833		37.43	na				
SP3A	20.833		37.44	na				
SP4	20.833		37.44	na				
SP4X	20.833		37.48	na				
SP5	20.833		37.51	na				
SP6	20.833		37.53	na				
SP7	20.833		37.54	na				
SP8	10.25		42.13	na				
TOS	10.25		42.14	na				
BOS	5.0		44.42	na				
FLG	1.0		53.2	na				
CH1	-5.0		55.8	na				
UG1	-5.0		55.81	na	150.0			
UG2	-5.0		48.6	na				
UG3	-5.0		46.3	na				
CT1	-5.0		54.09	na				
CT2	-5.0		53.55	na				
CT3	-5.0		53.05	na				

Flow Summary - Standard

Ranger Fire Inc
Summit Square III

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
CTY	2.5		50.44	na				

The maximum velocity is 17.16 and it occurs in the pipe between nodes T74 and B74

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S70 to 401	18.42 18.42	0.874 150.0 0.1798	1N 1O	7.0 3.0 0.0	3.667 10.000 13.667	14.126 -0.181 2.458			K Factor = 4.90 Vel = 9.85	
	0.0 18.42						16.403		K Factor = 4.55	
S71 to 401	18.42 18.42	0.874 150.0 0.1798	1N 1O	7.0 3.0 0.0	3.667 10.000 13.667	14.126 -0.181 2.458			K Factor = 4.90 Vel = 9.85	
	0.0 18.42						16.403		K Factor = 4.55	
400 to 401	-19.96 -19.96	1.394 150.0 -0.0215	1N	8.0 0.0 0.0	131.000 8.000 139.000	19.388 0.0 -2.985			Vel = 4.20	
401 to 402	36.84 16.88	1.394 150.0 0.0158	3N	24.0 0.0 0.0	146.167 24.000 170.167	16.403 0.0 2.681			Vel = 3.55	
402 to 400	0.0 16.88	1.394 150.0 0.0157	1O	6.0 0.0 0.0	13.333 6.000 19.333	19.084 0.0 0.304			Vel = 3.55	
	0.0 16.88						19.388		K Factor = 3.83	
400 to TOD2	36.83 36.83	1.394 150.0 0.0667	1N	8.0 0.0 0.0	81.500 8.000 89.500	19.388 0.0 5.973			Vel = 7.74	
TOD2 to BOD2	0.0 36.83	1.61 120.0 0.0500	1E 1Dvc	4.0 3.0 0.0	5.500 7.000 12.500	25.361 2.382 0.625			Vel = 5.80	
BOD2 to BOD1	0.0 36.83	1.61 120.0 0.0500	1T	8.0 0.0 0.0	2.000 8.000 10.000	28.368 0.0 0.500			Vel = 5.80	
BOD1 to DPVF	0.0 36.83	1.61 120.0 0.0500	1E	4.0 0.0 0.0	15.084 4.000 19.084	28.868 6.533 0.954			Vel = 5.80	
DPVF to SP2	0.0 36.83	1.61 120.0 0.0500	1T	8.0 0.0 0.0	13.417 8.000 21.417	36.355 0.0 1.071			Vel = 5.80	
	0.0 36.83						37.426		K Factor = 6.02	
S72 to B72	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	9.833 3.000 12.833	24.956 4.259 0.0			Vel = 0	
B72 to B76	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	8.750 3.000 11.750	29.215 0.0 0.0			Vel = 0	
B76 to 307	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	7.167 3.000 10.167	29.215 0.0 0.0			Vel = 0	
	0.0									

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0					29.215			K Factor = 0	
S73 to B73	0.0	0.874 150.0	3N 1O	21.0 3.0	16.000 24.000	24.618 4.439				
	0.0	0.0		0.0	40.000	0.0			Vel = 0	
B73 to 303	0.0	0.874 150.0	1N 1O	7.0 3.0	4.167 10.000	29.057 0.0				
	0.0	0.0		0.0	14.167	0.0			Vel = 0	
	0.0					29.057			K Factor = 0	
S74 to T74	16.05	0.874 150.0	1O	3.0 0.0	0.167 3.000	13.300 0.0			K Factor = 4.40	
	16.05	0.1392		0.0	3.167	0.441			Vel = 8.58	
T74 to B74	16.04	0.874 150.0	1O	3.0 0.0	9.833 3.000	13.741 4.259				
	32.09	0.5025		0.0	12.833	6.448			Vel = 17.16	
B74 to 305	0.0	0.874 150.0	1O	3.0 0.0	6.000 3.000	24.448 0.0				
	32.09	0.5023		0.0	9.000	4.521			Vel = 17.16	
	0.0					28.969			K Factor = 5.96	
S75 to T74	16.05	0.874 150.0	1O	3.0 0.0	0.167 3.000	13.300 0.0			K Factor = 4.40	
	16.05	0.1392		0.0	3.167	0.441			Vel = 8.58	
	0.0					13.741			K Factor = 4.33	
S76 to B76	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	24.956 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	
	0.0					29.215			K Factor = 0	
S77 to T77	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	24.765 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
T77 to B77	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	24.765 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	
B77 to 306	0.0	0.874 150.0	1N 1O	7.0 3.0	3.333 10.000	29.024 0.0				
	0.0	0.0		0.0	13.333	0.0			Vel = 0	
	0.0					29.024			K Factor = 0	
S78 to T77	0.0	0.874 150.0	1O	3.0 0.0	0.167 3.000	24.765 0.0				
	0.0	0.0		0.0	3.167	0.0			Vel = 0	
	0.0					24.765			K Factor = 0	
S79 to B79	0.0	0.874 150.0	1O	3.0 0.0	9.833 3.000	24.765 4.259				
	0.0	0.0		0.0	12.833	0.0			Vel = 0	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
B79 to 306	0.0 0.0 0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	6.250 10.000 16.250	29.024 0.0 0.0				
	0.0					29.024			K Factor = 0	
S60 to B60	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	9.833 3.000 12.833	25.075 4.259 0.0				
									Vel = 0	
B60 to 302A	0.0 0.0	0.874 150.0 0.0	2N 1O	14.0 3.0 0.0	15.750 17.000 32.750	29.334 13.318 -0.001				
	0.0								Vel = 0	
	0.0					42.651			K Factor = 0	
S61 to B61	0.0 0.0	0.874 150.0 -0.0001	1O	3.0 0.0 0.0	9.833 3.000 12.833	24.772 4.259 -0.001				
									Vel = 0	
B61 to 304	0.0 0.0	0.874 150.0 0.0	2N 1O	14.0 3.0 0.0	7.750 17.000 24.750	29.030 0.0 0.0				
	0.0								Vel = 0	
	0.0					29.030			K Factor = 0	
S62 to B62	0.0 0.0	0.874 150.0 -0.0001	1O	3.0 0.0 0.0	9.833 3.000 12.833	25.268 4.259 -0.001				
									Vel = 0	
B62 to 301	0.0 0.0	0.874 150.0 0.0	2N 1O	14.0 3.0 0.0	9.834 17.000 26.834	29.526 0.0 0.0				
	0.0								Vel = 0	
	0.0					29.526			K Factor = 0	
S63 to B63	0.0 0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	9.833 3.000 12.833	24.956 4.259 0.0				
									Vel = 0	
B63 to 307	0.0 0.0	0.874 150.0 0.0	2N 1O	14.0 3.0 0.0	9.584 17.000 26.584	29.215 0.0 0.0				
	0.0								Vel = 0	
	0.0					29.215			K Factor = 0	
300 to 301	-12.34 -12.34	1.394 150.0 -0.0088	5N 1O	40.0 6.0 0.0	117.167 46.000 163.167	30.967 0.0 -1.441				
									Vel = 2.59	
301 to 302	0.0 -12.34	1.394 150.0 -0.0088	1O	6.0 0.0 0.0	15.833 6.000 21.833	29.526 0.0 -0.192				
									Vel = 2.59	
302 to 303	0.0 -12.34	1.394 150.0 -0.0088	1N	8.0 0.0 0.0	23.333 8.000 31.333	29.334 0.0 -0.277				
									Vel = 2.59	
303 to 304	0.0 -12.34	1.394 150.0 -0.0090		0.0 0.0 0.0	3.000 0.0 3.000	29.057 0.0 -0.027				
									Vel = 2.59	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 8
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
304 to 305	0.0 -12.34	1.394 150.0 -0.0088		0.0 0.0 0.0	6.917 0.0 6.917	29.030 0.0 -0.061			Vel = 2.59	
305 to 306	32.09 19.75	1.394 150.0 0.0213		0.0 0.0 0.0	2.583 0.0 2.583	28.969 0.0 0.055			Vel = 4.15	
306 to 307	0.0 19.75	1.394 150.0 0.0210		0.0 0.0 0.0	9.083 0.0 9.083	29.024 0.0 0.191			Vel = 4.15	
307 to 300	0.0 19.75	1.394 150.0 0.0211	1O	6.0 0.0 0.0	77.167 6.000 83.167	29.215 0.0 1.752			Vel = 4.15	
	0.0 19.75					30.967			K Factor = 3.55	
302 to 302A	0.0 0.0	1.394 150.0 -0.0002		0.0 0.0 0.0	4.500 0.0 4.500	29.334 13.318 -0.001			Vel = 0	
	0.0 0.0					42.651			K Factor = 0	
300 to 3RD	32.09 32.09	1.682 120.0 0.0313	3E 1Ball	14.849 3.094 0.0	35.833 17.943 53.776	30.967 0.0 1.684			Vel = 4.63	
3RD to 2ND	0.0 32.09	1.682 120.0 0.0313	1E	4.95 0.0 0.0	9.917 4.950 14.867	32.651 4.295 0.466			Vel = 4.63	
2ND to SP3A	0.0 32.09	4.26 120.0 0.0003	1E 1T	13.167 26.334 0.0	30.167 39.501 69.668	37.412 0.0 0.023			Vel = 0.72	
	0.0 32.09					37.435			K Factor = 5.24	
SP2 to SP3	36.83 36.83	6.357 120.0 0.0001	1E	17.603 0.0 0.0	16.917 17.603 34.520	37.426 0.0 0.002			Vel = 0.37	
SP3 to SP3A	0.0 36.83	6.357 120.0 0.0001	1T	37.72 0.0 0.0	77.250 37.720 114.970	37.428 0.0 0.007			Vel = 0.37	
SP3A to SP4	32.10 68.93	6.357 120.0 0.0002	1T	37.72 0.0 0.0	2.000 37.720 39.720	37.435 0.0 0.008			Vel = 0.70	
SP4 to SP4X	0.0 68.93	6.357 120.0 0.0002	1T	37.72 0.0 0.0	128.083 37.720 165.803	37.443 0.0 0.033			Vel = 0.70	
SP4X to SP5	0.0 68.93	6.357 120.0 0.0002	2E 1F	35.205 8.801 0.0	132.417 44.006 176.423	37.476 0.0 0.035			Vel = 0.70	
SP5 to SP6	0.0 68.93	6.357 120.0 0.0002	1T	37.72 0.0 0.0	71.750 37.720 109.470	37.511 0.0 0.022			Vel = 0.70	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 9
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP6 to SP7	0.0 68.93	6.357 120.0 0.0002	2E	35.205 0.0 0.0	25.417 35.205 60.622	37.533 0.0 0.012			Vel = 0.70	
SP7 to SP8	0.0 68.93	6.357 120.0 0.0002	1E	17.603 0.0 0.0	10.583 17.603 28.186	37.545 4.584 0.005			Vel = 0.70	
SP8 to TOS	0.0 68.93	6.357 120.0 0.0002	1E	17.603 0.0 0.0	11.833 17.603 29.436	42.134 0.0 0.006			Vel = 0.70	
TOS to BOS	0.0 68.93	6.357 120.0 0.0002	1T	37.72 0.0 0.0	5.250 37.720 42.970	42.140 2.274 0.008			Vel = 0.70	
BOS to FLG	0.0 68.93	3.26 140.0 0.0038	1Zcb	0.0 0.0 0.0	4.000 0.0 4.000	44.422 8.766 0.015			** Fixed Loss = 7.033 Vel = 2.65	
FLG to CH1	0.0 68.93	8.27 140.0 0.0001	1E	28.468 0.0 0.0	11.000 28.468 39.468	53.203 2.599 0.002			Vel = 0.41	
CH1 to UG1	0.0 68.93	7.68 150.0 0.0001	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	55.804 0.0 0.006			Vel = 0.48	
	0.0 68.93					55.810			K Factor = 9.23	
UG1 to UG2	-929.99 -929.99	7.68 150.0 -0.0064	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	55.810 0.0 -7.210			Qa = 150 Vel = 6.44	
UG2 to UG3	0.0 -929.99	7.68 150.0 -0.0064	1T	43.857 0.0 0.0	312.417 43.857 356.274	48.600 0.0 -2.297			Vel = 6.44	
UG3 to CT1	0.0 -929.99	7.68 150.0 -0.0065	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	46.303 8.283 -0.497			** Fixed Loss = 8.283 Vel = 6.44	
CT1 to CT2	0.0 -929.99	11.2 150.0 -0.0010	1T	66.446 0.0 0.0	456.417 66.446 522.863	54.089 0.0 -0.537			Vel = 3.03	
CT2 to CT3	-218.93 -1148.92	11.2 150.0 -0.0015	1T	66.446 0.0 0.0	267.583 66.446 334.029	53.552 0.0 -0.507			Vel = 3.74	
CT3 to UG1	0.0 -1148.92	5.86 150.0 -0.0356	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	53.045 11.290 -8.525			** Fixed Loss = 11.29 Vel = 13.67	
	0.0 -1148.92					55.810			K Factor = -153.79	
CT2 to CTY	218.93 218.93	6.16 140.0 0.0015	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	53.552 -3.248 0.133			Vel = 2.36	
	0.0 218.93					50.437			K Factor = 30.83	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 10
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
-----------------------	--------------	----------------------	---------------------------	-------------------------	----------------	----------------	-------	-------	-------



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 1 Section B Clubhouse Wet System Remote 8.WXF

Water Supply Curve C

Ranger Fire Inc
Summit Square III


Page 1
Date

City Water Supply:

C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:

D1 - Elevation : 7.471
D2 - System Flow : 257.782
D2 - System Pressure : 77.501
Hose (Demand) : 150
D3 - System Demand : 407.782
Safety Margin : 11.565



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zcb	Colt C200 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S90	19.75	5.6	12.32	na	19.66	0.1	146	7.0
T91	20.167		16.12	na				
S91	19.75	5.6	15.44	na	22.01	0.1	148	7.0
S92	19.75	5.6	22.83	na	26.75	0.1	130	7.0
S93	19.75	5.6	24.05	na	27.46	0.1	130	7.0
S94	19.75	5.6	13.53	na	20.6	0.1	206	7.0
T95	20.167		17.35	na				
S95	19.75	5.6	16.62	na	22.83	0.1	199	7.0
S96	19.75	5.6	22.9	na	26.8	0.1	199	7.0
S97	19.75	5.6	14.07	na	21.0	0.1	206	7.0
T98	20.167		17.94	na				
S98	19.75	5.6	17.18	na	23.21	0.1	199	7.0
S99	19.75	5.6	17.6	na	23.49	0.1	45	7.0
T100	20.167		21.65	na				
S100	19.75	5.6	18.32	na	23.97	0.1	130	7.0
200	20.167		38.3	na				
201	20.167		30.8	na				
202	20.167		29.37	na				
203	20.167		28.42	na				
204	20.167		28.33	na				
205	20.167		28.33	na				
2ND	20.167		56.1	na				
SP2	20.833		64.93	na				
SP3	20.833		64.93	na				
SP3A	20.833		64.93	na				
SP4	20.833		65.02	na				
SP5	20.833		65.8	na				
SP6	20.833		66.05	na				
SP7	20.833		66.12	na				
SP8	10.25		70.77	na				
TOS	10.25		70.86	na				
BOS	5.0		73.24	na				
FLG	1.0		78.87	na				
CH1	-5.0		81.49	na				
UG1	-5.0		81.56	na	150.0			
UG2	-5.0		75.0	na				
UG3	-5.0		72.91	na				
CT1	-5.0		80.82	na				
CT2	-5.0		80.33	na				
CT3	-5.0		79.7	na				
CTY	2.5		77.5	na				

The maximum velocity is 25.38 and it occurs in the pipe between nodes T100 and 201

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S90 to T91	19.66 19.66	0.874 150.0 0.2029	1N	7.0 0.0 0.0	12.583 7.000 19.583	12.324 -0.181 3.974			K Factor = 5.60 Vel = 10.51	
T91 to 205	22.01 41.67	0.874 150.0 0.8143	1O	3.0 0.0 0.0	12.000 3.000 15.000	16.117 0.0 12.215			Vel = 22.28	
	0.0 41.67					28.332			K Factor = 7.83	
S91 to T91	22.01 22.01	0.874 150.0 0.2499	1O	3.0 0.0 0.0	0.417 3.000 3.417	15.444 -0.181 0.854			K Factor = 5.60 Vel = 11.77	
	0.0 22.01					16.117			K Factor = 5.48	
S92 to 204	26.75 26.75	0.874 150.0 0.3589	1N 1O	7.0 3.0 0.0	5.833 10.000 15.833	22.825 -0.181 5.682			K Factor = 5.60 Vel = 14.31	
	0.0 26.75					28.326			K Factor = 5.03	
S93 to 204	27.46 27.46	0.874 150.0 0.3766	2O	6.0 0.0 0.0	5.834 6.000 11.834	24.050 -0.181 4.457			K Factor = 5.60 Vel = 14.68	
	0.0 27.46					28.326			K Factor = 5.16	
S94 to T95	20.60 20.6	0.874 150.0 0.2212	1N	7.0 0.0 0.0	11.084 7.000 18.084	13.532 -0.181 4.001			K Factor = 5.60 Vel = 11.02	
T95 to 203	22.83 43.43	0.874 150.0 0.8793	1O	3.0 0.0 0.0	9.583 3.000 12.583	17.352 0.0 11.064			Vel = 23.23	
	0.0 43.43					28.416			K Factor = 8.15	
S95 to T95	22.83 22.83	0.874 150.0 0.2675	1O	3.0 0.0 0.0	0.417 3.000 3.417	16.619 -0.181 0.914			K Factor = 5.60 Vel = 12.21	
	0.0 22.83					17.352			K Factor = 5.48	
S96 to 203	26.80 26.8	0.874 150.0 0.3599	1N 1O	7.0 3.0 0.0	5.834 10.000 15.834	22.898 -0.181 5.699			K Factor = 5.60 Vel = 14.33	
	0.0 26.80					28.416			K Factor = 5.03	
S97 to T98	21.00 21.0	0.874 150.0 0.2294	1N	7.0 0.0 0.0	10.667 7.000 17.667	14.067 -0.181 4.052			K Factor = 5.60 Vel = 11.23	
T98 to 202	23.21 44.21	0.874 150.0 0.9088	1O	3.0 0.0 0.0	9.583 3.000 12.583	17.938 0.0 11.435			Vel = 23.64	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 44.21					29.373			K Factor = 8.16	
S98 to T98	23.21	0.874 150.0 0.2760	1O	3.0 0.0 0.0	0.417 3.000 3.417	17.176 -0.181 0.943			K Factor = 5.60 Vel = 12.41	
	0.0 23.21					17.938			K Factor = 5.48	
S99 to T100	23.49	0.874 150.0 0.2821	1N	7.0 0.0 0.0	8.000 7.000 15.000	17.600 -0.181 4.232			K Factor = 5.60 Vel = 12.56	
T100 to 201	23.97	0.874 150.0 1.0361	1O	3.0 0.0 0.0	5.833 3.000 8.833	21.651 0.0 9.152			Vel = 25.38	
	0.0 47.46					30.803			K Factor = 8.55	
S100 to T100	23.97	0.874 150.0 0.2928	1N 1O	7.0 3.0 0.0	2.000 10.000 12.000	18.318 -0.181 3.514			K Factor = 5.60 Vel = 12.82	
	0.0 23.97					21.651			K Factor = 5.15	
200 to 201	-191.86	2.003 150.0 -0.2419		0.0 0.0 0.0	31.000 0.0 31.000	38.303 0.0 -7.500			Vel = 19.53	
201 to 202	47.46	2.003 150.0 -0.1430		0.0 0.0 0.0	10.000 0.0 10.000	30.803 0.0 -1.430			Vel = 14.70	
202 to 203	44.21	2.003 150.0 -0.0727		0.0 0.0 0.0	13.167 0.0 13.167	29.373 0.0 -0.957			Vel = 10.20	
203 to 204	70.23	2.003 150.0 -0.0078		0.0 0.0 0.0	11.500 0.0 11.500	28.416 0.0 -0.090			Vel = 3.05	
204 to 205	54.21	2.003 150.0 0.0048		0.0 0.0 0.0	1.250 0.0 1.250	28.326 0.0 0.006			Vel = 2.47	
205 to 200	41.67	2.003 150.0 0.0335	8N 1O	88.0 10.0 0.0	199.417 98.000 297.417	28.332 0.0 9.971			Vel = 6.71	
	0.0 65.92					38.303			K Factor = 10.65	
200 to 2ND	257.78	2.635 120.0 0.1661	3E 1B 1T 1S	24.711 9.61 16.474 19.22	37.167 70.015 107.182	38.303 0.0 17.799			Vel = 15.17	
2ND to SP3A	0.0	2.635 120.0 0.1661	3E	24.711 0.0 0.0	30.167 24.711 54.878	56.102 -0.288 9.113			Vel = 15.17	
	0.0									

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	257.78					64.927			K Factor = 31.99	
SP2 to SP3	0.0	6.357 120.0	1E	17.603 0.0	16.917 17.603	64.927 0.0				
	0.0	0.0		0.0	34.520	0.0			Vel = 0	
SP3 to SP3A	0.0	6.357 120.0		0.0 0.0	75.250 0.0	64.927 0.0				
	0.0	0.0		0.0	75.250	0.0			Vel = 0	
SP3A to SP4	257.78	6.357 120.0	1T	37.72 0.0	1.917 37.720	64.927 0.0				
	257.78	0.0023		0.0	39.637	0.090			Vel = 2.61	
SP4 to SP5	0.0	6.357 120.0	2E 1F	35.205 8.801	260.500 81.726	65.017 0.0				
	257.78	0.0023	1T	37.72	342.226	0.780			Vel = 2.61	
SP5 to SP6	0.0	6.357 120.0	1T	37.72 0.0	71.750 37.720	65.797 0.0				
	257.78	0.0023		0.0	109.470	0.249			Vel = 2.61	
SP6 to SP7	0.0	6.357 120.0	1E	17.603 0.0	16.167 17.603	66.046 0.0				
	257.78	0.0023		0.0	33.770	0.077			Vel = 2.61	
SP7 to SP8	0.0	6.357 120.0	1E	17.603 0.0	10.583 17.603	66.123 4.584				
	257.78	0.0023		0.0	28.186	0.064			Vel = 2.61	
SP8 to TOS	0.0	6.357 120.0	2E	35.205 0.0	5.917 35.205	70.771 0.0				
	257.78	0.0023		0.0	41.122	0.094			Vel = 2.61	
TOS to BOS	0.0	6.357 120.0	1T	37.72 0.0	5.250 37.720	70.865 2.274				
	257.78	0.0023		0.0	42.970	0.097			Vel = 2.61	
BOS to FLG	0.0	3.26 140.0	1Zcb	0.0 0.0	4.000 0.0	73.236 5.461				
	257.78	0.0445		0.0	4.000	0.178			* * Fixed Loss = 3.729 Vel = 9.91	
FLG to CH1	0.0	8.27 140.0	1E	28.468 0.0	11.000 28.468	78.875 2.599				
	257.78	0.0005		0.0	39.468	0.018			Vel = 1.54	
CH1 to UG1	0.0	7.68 150.0	1T 1B	43.857 15.037	56.500 58.894	81.492 0.0				
	257.78	0.0006		0.0	115.394	0.069			Vel = 1.79	
	0.0 257.78					81.561			K Factor = 28.54	
UG1 to UG2	-883.63	7.68 150.0	4F 1T	45.11 43.857	1029.417 88.967	81.561 0.0			Qa = 150	
	-883.63	-0.0059		0.0	1118.384	-6.559			Vel = 6.12	
UG2 to UG3	0.0	7.68 150.0	1T	43.857 0.0	312.417 43.857	75.002 0.0				
	-883.63	-0.0059		0.0	356.274	-2.089			Vel = 6.12	
UG3 to CT1	0.0	7.68 150.0	1T 1Zcg	43.857 0.0	33.117 43.857	72.913 8.357				
	-883.63	-0.0059		0.0	76.974	-0.452			* * Fixed Loss = 8.357 Vel = 6.12	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CT1 to CT2	0.0 -883.63	11.2 150.0 -0.0009	1T	66.446 0.0 0.0	456.417 66.446 522.863	80.818 0.0 -0.488			Vel = 2.88	
CT2 to CT3	-407.78 -1291.41	11.2 150.0 -0.0019	1T	66.446 0.0 0.0	267.583 66.446 334.029	80.330 0.0 -0.629			Vel = 4.21	
CT3 to UG1	0.0 -1291.41	5.86 150.0 -0.0442	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	79.701 12.446 -10.586			* * Fixed Loss = 12.446 Vel = 15.36	
	0.0 -1291.41					81.561			K Factor = -143.00	
CT2 to CTY	407.78 407.78	6.16 140.0 0.0047	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	80.330 -3.248 0.419			Vel = 4.39	
	0.0 407.78					77.501			K Factor = 46.32	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square
Building :
Location :
System :
Contract :
Data File : Building 2 Section F Low Pressure Dry System Remote 9.WXF

Water Supply Curve C

Ranger Fire Inc
Summit Square


Page 1
Date

City Water Supply:

C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:

D1 - Elevation : 2.851
D2 - System Flow : 49.177
D2 - System Pressure : 38.559
Hose (Demand) : 150
D3 - System Demand : 199.177
Safety Margin : 51.193



Fittings Used Summary

Ranger Fire Inc
Summit Square

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S100	9.083	5.6	7.0	na	14.82	0.15	92	7.0
T101	9.5		8.73	na				
S101	9.083	5.6	8.42	na	16.25	0.15	92	7.0
S102	9.083	5.6	10.46	na	18.11	0.15	110	7.0
S110	9.083		14.78	na				
S111	9.083		14.78	na				
S112	9.083		14.9	na				
T113	9.5		14.72	na				
S113	9.083		14.9	na				
100	9.5		16.71	na				
101	9.5		12.12	na				
102	9.5		14.59	na				
103	9.5		14.72	na				
TOD4	9.5		19.47	na				
BOD4	4.0		22.8	na				
DPVF	20.833		17.99	na				
SPX	20.833		19.02	na				
SPX1	20.833		19.04	na				
SP13	20.833		19.05	na				
SP14	20.833		19.05	na				
SP15	10.25		23.64	na				
TOS	10.25		23.64	na				
BOS	5.0		25.92	na				
FLG	1.0		33.41	na				
CH2	-5.0		36.01	na				
UG1	-5.0		44.64	na				
UG2	-5.0		36.01	na	150.0			
UG3	-5.0		34.17	na				
CT1	-5.0		42.13	na				
CT2	-5.0		41.7	na				
CT3	-5.0		41.29	na				
CTY	2.5		38.56	na				

The maximum velocity is 16.62 and it occurs in the pipe between nodes T101 and 101

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S100 to T101	14.82	0.874 150.0 0.1203	1N	7.0 0.0 0.0	8.888 7.000 15.888	7.000 -0.181 1.911			K Factor = 5.60	
T101 to 101	16.25	0.874 150.0 0.4731	1O	3.0 0.0 0.0	4.167 3.000 7.167	8.730 0.0 3.391			Vel = 7.93	
	0.0 31.07					12.121			K Factor = 8.92	
S101 to T101	16.25	0.874 150.0 0.1428	1O	3.0 0.0 0.0	0.417 3.000 3.417	8.423 -0.181 0.488			K Factor = 5.60	
	0.0 16.25					8.730			Vel = 8.69	
S102 to 101	18.11	0.874 150.0 0.1743	2O	6.0 0.0 0.0	4.584 6.000 10.584	10.457 -0.181 1.845			K Factor = 5.50	
	0.0 18.11					12.121			K Factor = 5.60	
S110 to 102	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	11.917 10.000 21.917	14.775 -0.181 0.001			Vel = 9.68	
	0.0 0.0					14.595			K Factor = 5.20	
S111 to 102	0.0	0.874 150.0 0.0001	1N 1O	7.0 3.0 0.0	2.167 10.000 12.167	14.775 -0.181 0.001			Vel = 0	
	0.0 0.0					14.595			K Factor = 0	
S112 to T113	0.0	0.874 150.0 0.0	1N	7.0 0.0 0.0	5.000 7.000 12.000	14.900 -0.181 0.0			Vel = 0	
T113 to 103	0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	6.833 3.000 9.833	14.719 0.0 0.0			Vel = 0	
	0.0 0.0					14.719			K Factor = 0	
S113 to T113	0.0	0.874 150.0 0.0	1N 1O	7.0 3.0 0.0	9.167 10.000 19.167	14.900 -0.181 0.0			Vel = 0	
	0.0 0.0					14.719			K Factor = 0	
100 to 101	-24.99	1.598 150.0 -0.0167	3N	27.0 0.0 0.0	246.833 27.000 273.833	16.707 0.0 -4.586			Vel = 4.00	
101 to 102	49.17	1.598 150.0 0.0158	4N	36.0 0.0 0.0	121.000 36.000 157.000	12.121 0.0 2.474			Vel = 3.87	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square

Page 5
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
102 to 103	0.0 24.18	1.598 150.0 0.0157		0.0 0.0 0.0	7.917 0.0 7.917	14.595 0.0 0.124			Vel = 3.87	
103 to 100	0.0 24.18	1.598 150.0 0.0158	1N 1O	9.0 8.0 0.0	109.167 17.000 126.167	14.719 0.0 1.988			Vel = 3.87	
	0.0 24.18					16.707			K Factor = 5.92	
100 to TOD4	49.18 49.18	1.598 150.0 0.0586	1N	9.0 0.0 0.0	38.250 9.000 47.250	16.707 0.0 2.768			Vel = 7.87	
TOD4 to BOD4	0.0 49.18	1.61 120.0 0.0854	1Dvc 1Ball	3.0 2.5 0.0	5.500 5.500 11.000	19.475 2.382 0.939			Vel = 7.75	
BOD4 to DPVF	0.0 49.18	1.61 120.0 0.0853	2E	8.0 0.0 0.0	21.083 8.000 29.083	22.796 -7.290 2.481			Vel = 7.75	
DPVF to SPX	0.0 49.18	1.61 120.0 0.0854	1T	8.0 0.0 0.0	4.083 8.000 12.083	17.987 0.0 1.032			Vel = 7.75	
	0.0 49.18					19.019			K Factor = 11.28	
SPX to SPX1	49.18 49.18	6.357 120.0 0.0001	1E 1T	17.603 37.72 0.0	120.333 55.323 175.656	19.019 0.0 0.018			Vel = 0.50	
SPX1 to SP13	0.0 49.18	6.357 120.0 0.0001	1E 1T	17.603 37.72 0.0	29.917 55.323 85.240	19.037 0.0 0.009			Vel = 0.50	
SP13 to SP14	0.0 49.18	6.357 120.0 0.0001	2E	35.205 0.0 0.0	33.500 35.205 68.705	19.046 0.0 0.008			Vel = 0.50	
SP14 to SP15	0.0 49.18	6.357 120.0 0.0001	1E	17.603 0.0 0.0	10.583 17.603 28.186	19.054 4.584 0.002			Vel = 0.50	
SP15 to TOS	0.0 49.18	6.357 120.0 0.0001	2E	35.205 0.0 0.0	7.583 35.205 42.788	23.640 0.0 0.005			Vel = 0.50	
TOS to BOS	0.0 49.18	6.357 120.0 0.0001	1T 1B	37.72 12.573 0.0	5.250 50.293 55.543	23.645 2.274 0.005			Vel = 0.50	
BOS to FLG	0.0 49.18	2.157 120.0 0.0208	1Zaa	0.0 0.0 0.0	4.000 0.0 4.000	25.924 7.404 0.083			* * Fixed Loss = 5.672 Vel = 4.32	
FLG to CH2	0.0 49.18	8.27 140.0 0.0	1E	28.468 0.0 0.0	11.000 28.468 39.468	33.411 2.599 0.0			Vel = 0.29	
CH2 to UG2	0.0 49.18	7.68 150.0 0.0	1T	43.857 0.0 0.0	36.167 43.857 80.024	36.010 0.0 0.003			Vel = 0.34	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 49.18					36.013			K Factor = 8.20	
UG1 to UG2	-1024.64	7.68 150.0	4F 1T	45.11 43.857	1029.417 88.967	44.639 0.0				
	-1024.64	-0.0077		0.0	1118.384	-8.626			Vel = 7.10	
UG2 to UG3	199.17	7.68 150.0	1T	43.857 0.0	312.417 43.857	36.013 0.0			Qa = 150	
	-825.47	-0.0052		0.0	356.274	-1.843			Vel = 5.72	
UG3 to CT1	0.0	7.68 150.0	1T 1Zcg	43.857 0.0	33.117 43.857	34.170 8.353			* * Fixed Loss = 8.353	
	-825.47	-0.0052		0.0	76.974	-0.397			Vel = 5.72	
CT1 to CT2	0.0	11.2 150.0	1T	66.446 0.0	456.417 66.446	42.126 0.0				
	-825.47	-0.0008		0.0	522.863	-0.431			Vel = 2.69	
CT2 to CT3	-199.17	11.2 150.0	1T	66.446 0.0	267.583 66.446	41.695 0.0				
	-1024.64	-0.0012		0.0	334.029	-0.410			Vel = 3.34	
CT3 to UG1	0.0	5.86 150.0	1T 1F	38.342 8.947	192.333 47.288	41.285 10.253			* * Fixed Loss = 10.253	
	-1024.64	-0.0288	1Zcg	0.0	239.621	-6.899			Vel = 12.19	
	0.0 -1024.64					44.639			K Factor = -153.36	
CT2 to CTY	199.18	6.16 140.0	1E 1G	20.084 4.304	22.500 67.425	41.695 -3.248				
	199.18	0.0012	1T	43.037	89.925	0.112			Vel = 2.14	
	0.0 199.18					38.559			K Factor = 32.08	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 2 Section F Low Pressure Dry System Remote 10.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 2.851
D2 - System Flow : 104.871
D2 - System Pressure : 78.701
Hose (Demand) : 150
D3 - System Demand : 254.871
Safety Margin : 10.908



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Ball	B Ball Milw BB-SC100			2.25	2	2.5	2.25	10													
Dvc	Dry Vic 768 NXT					3	9	8	17		21		22	50							
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90'Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S100	9.083		25.08	na				
T101	9.5		24.9	na				
S101	9.083		25.08	na				
S102	9.083		25.08	na				
S110	9.083	5.6	14.75	na	21.51	0.15	104	7.0
S111	9.083	5.6	16.73	na	22.91	0.15	104	7.0
S112	9.083	5.6	11.37	na	18.89	0.15	116	7.0
T113	9.5		13.45	na				
S113	9.083	5.6	10.33	na	18.0	0.15	120	7.0
S114	9.083	5.6	17.71	na	23.57	0.15	95	7.0
100	9.5		33.75	na				
101	9.5		24.9	na				
102	9.5		19.83	na				
103	9.5		19.85	na				
TOD4	9.5		44.99	na				
BOD4	4.0		51.18	na				
DPVF	20.833		53.97	na				
SPX	20.833		58.15	na				
SPX1	20.833		58.23	na				
SP13	20.833		58.26	na				
SP14	20.833		58.29	na				
SP15	10.25		62.89	na				
TOS	10.25		62.91	na				
BOS	5.0		65.21	na				
FLG	1.0		73.19	na				
CH2	-5.0		75.79	na				
UG1	-5.0		84.64	na				
UG2	-5.0		75.8	na	150.0			
UG3	-5.0		74.13	na				
CT1	-5.0		82.16	na				
CT2	-5.0		81.77	na				
CT3	-5.0		81.35	na				
CTY	2.5		78.7	na				

The maximum velocity is 19.73 and it occurs in the pipe between nodes T113 and 103

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S100 to T101	0.0	0.874 150.0 0.0001	1N	7.0 0.0 0.0	8.888 7.000 15.888	25.082 -0.181 0.001			Vel = 0	
T101 to 101	0.0	0.874 150.0 0.0	1O	3.0 0.0 0.0	4.167 3.000 7.167	24.902 0.0 0.0			Vel = 0	
	0.0 0.0					24.902			K Factor = 0	
S101 to T101	0.0	0.874 150.0 0.0003	1O	3.0 0.0 0.0	0.417 3.000 3.417	25.082 -0.181 0.001			Vel = 0	
	0.0 0.0					24.902			K Factor = 0	
S102 to 101	0.0	0.874 150.0 0.0001	2O	6.0 0.0 0.0	4.584 6.000 10.584	25.082 -0.181 0.001			Vel = 0	
	0.0 0.0					24.902			K Factor = 0	
S110 to 102	21.51	0.874 150.0 0.2397	1N 1O	7.0 3.0 0.0	11.917 10.000 21.917	14.755 -0.181 5.253			K Factor = 5.60 Vel = 11.50	
	0.0 21.51					19.827			K Factor = 4.83	
S111 to 102	22.91	0.874 150.0 0.2693	1N 1O	7.0 3.0 0.0	2.167 10.000 12.167	16.732 -0.181 3.276			K Factor = 5.60 Vel = 12.25	
	0.0 22.91					19.827			K Factor = 5.15	
S112 to T113	18.89	0.874 150.0 0.1884	1N	7.0 0.0 0.0	5.000 7.000 12.000	11.375 -0.181 2.261			K Factor = 5.60 Vel = 10.10	
T113 to 103	18.00	0.874 150.0 0.6500	1O	3.0 0.0 0.0	6.833 3.000 9.833	13.455 0.0 6.391			Vel = 19.73	
	0.0 36.89					19.846			K Factor = 8.28	
S113 to T113	18.00	0.874 150.0 0.1724	1N 1O	7.0 3.0 0.0	9.167 10.000 19.167	10.332 -0.181 3.304			K Factor = 5.60 Vel = 9.63	
	0.0 18.00					13.455			K Factor = 4.91	
S114 to 103	23.57	0.874 150.0 0.2837	2O	6.0 0.0 0.0	2.167 6.000 8.167	17.710 -0.181 2.317			K Factor = 5.60 Vel = 12.60	
	0.0 23.57					19.846			K Factor = 5.29	
100 to 101	-35.66	1.598 150.0 -0.0323	3N	27.0 0.0 0.0	246.833 27.000 273.833	33.753 0.0 -8.851			Vel = 5.70	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date


Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
101 to 102	0.0 -35.66	1.598 150.0 -0.0323	4N	36.0 0.0 0.0	121.000 36.000 157.000	24.902 0.0 -5.075			Vel = 5.70	
102 to 103	44.42 8.76	1.598 150.0 0.0024		0.0 0.0 0.0	7.917 0.0 7.917	19.827 0.0 0.019			Vel = 1.40	
103 to 100	60.45 69.21	1.598 150.0 0.1102	1N 1O	9.0 8.0 0.0	109.167 17.000 126.167	19.846 0.0 13.907			Vel = 11.07	
	0.0 69.21					33.753			K Factor = 11.91	
100 to TOD4	104.87 104.87	1.598 150.0 0.2378	1N	9.0 0.0 0.0	38.250 9.000 47.250	33.753 0.0 11.234			Vel = 16.78	
TOD4 to BOD4	0.0 104.87	1.61 120.0 0.3465	1Dvc 1Ball	3.0 2.5 0.0	5.500 5.500 11.000	44.987 2.382 3.811			Vel = 16.53	
BOD4 to DPVF	0.0 104.87	1.61 120.0 0.3464	2E	8.0 0.0 0.0	21.083 8.000 29.083	51.180 -7.290 10.075			Vel = 16.53	
DPVF to SPX	0.0 104.87	1.61 120.0 0.3464	1T	8.0 0.0 0.0	4.083 8.000 12.083	53.965 0.0 4.186			Vel = 16.53	
	0.0 104.87					58.151			K Factor = 13.75	
SPX to SPX1	104.87 104.87	6.357 120.0 0.0004	1E 1T	17.603 37.72 0.0	120.333 55.323 175.656	58.151 0.0 0.076			Vel = 1.06	
SPX1 to SP13	0.0 104.87	6.357 120.0 0.0004	1E 1T	17.603 37.72 0.0	29.917 55.323 85.240	58.227 0.0 0.037			Vel = 1.06	
SP13 to SP14	0.0 104.87	6.357 120.0 0.0004	2E	35.205 0.0 0.0	33.500 35.205 68.705	58.264 0.0 0.029			Vel = 1.06	
SP14 to SP15	0.0 104.87	6.357 120.0 0.0004	1E	17.603 0.0 0.0	10.583 17.603 28.186	58.293 4.584 0.012			Vel = 1.06	
SP15 to TOS	0.0 104.87	6.357 120.0 0.0004	2E	35.205 0.0 0.0	7.583 35.205 42.788	62.889 0.0 0.018			Vel = 1.06	
TOS to BOS	0.0 104.87	6.357 120.0 0.0004	1T 1B	37.72 12.573 0.0	5.250 50.293 55.543	62.907 2.274 0.024			Vel = 1.06	
BOS to FLG	0.0 104.87	2.157 120.0 0.0835	1Zaa	0.0 0.0 0.0	4.000 0.0 4.000	65.205 7.652 0.334			* * Fixed Loss = 5.92 Vel = 9.21	
FLG to CH2	0.0 104.87	8.27 140.0 0.0001	1E	28.468 0.0 0.0	11.000 28.468 39.468	73.191 2.599 0.003			Vel = 0.63	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CH2 to UG2	0.0 104.87	7.68 150.0 0.0001	1T	43.857 0.0 0.0	36.167 43.857 80.024	75.793 0.0 0.009			Vel = 0.73	
	0.0 104.87					75.802			K Factor = 12.05	
UG1 to UG2	-1038.31 -1038.31	7.68 150.0 -0.0079	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	84.642 0.0 -8.840			Vel = 7.19	
UG2 to UG3	254.87 -783.44	7.68 150.0 -0.0047	1T	43.857 0.0 0.0	312.417 43.857 356.274	75.802 0.0 -1.672			Qa = 150 Vel = 5.43	
UG3 to CT1	0.0 -783.44	7.68 150.0 -0.0047	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	74.130 8.396 -0.362			* * Fixed Loss = 8.396 Vel = 5.43	
CT1 to CT2	0.0 -783.44	11.2 150.0 -0.0007	1T	66.446 0.0 0.0	456.417 66.446 522.863	82.164 0.0 -0.391			Vel = 2.55	
CT2 to CT3	-254.87 -1038.31	11.2 150.0 -0.0013	1T	66.446 0.0 0.0	267.583 66.446 334.029	81.773 0.0 -0.420			Vel = 3.38	
CT3 to UG1	0.0 -1038.31	5.86 150.0 -0.0295	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	81.353 10.360 -7.071			* * Fixed Loss = 10.36 Vel = 12.35	
	0.0 -1038.31					84.642			K Factor = -112.86	
CT2 to CTY	254.87 254.87	6.16 140.0 0.0020	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	81.773 -3.248 0.176			Vel = 2.74	
	0.0 254.87					78.701			K Factor = 28.73	



. . . Fire Protection by Computer Design

Ranger Fire Inc
1260 Eastex Freeway
Houston, TX 77039

Job Name : Summit Square III
Building :
Location :
System :
Contract :
Data File : Building 2 Section G Remote 11.WXF


Water Supply Curve C

Ranger Fire Inc
Summit Square III

Page 1
Date

City Water Supply:
C1 - Static Pressure : 90
C2 - Residual Pressure: 68
C2 - Residual Flow : 2250

Demand:
D1 - Elevation : 2.851
D2 - System Flow : 193.703
D2 - System Pressure : 77.043
Hose (Demand) : 150
D3 - System Demand : 343.703
Safety Margin : 12.277



Fittings Used Summary

Ranger Fire Inc
Summit Square III

Page 2
Date

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N *	CPVC 90' Ell Harvel-Spears		7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O *	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			
Zcg	Colt C400 Horz OSY	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

Ranger Fire Inc
Summit Square III

Page 3
Date

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
S200	9.083	5.6	17.25	na	23.26	0.15	117	7.0
B200	20.167		22.54	na				
S201	9.083	5.6	13.61	na	20.66	0.15	130	7.0
B201	20.167		19.39	na				
S202	9.083	5.6	16.71	na	22.89	0.15	130	7.0
B202	20.167		21.73	na				
S203	9.083	5.6	10.68	na	18.3	0.15	122	7.0
T204	9.5		14.08	na				
B204	20.167		18.04	na				
S204	9.083	5.6	13.51	na	20.58	0.15	122	7.0
S205	9.083	5.6	28.6	na	29.95	0.15	120	7.0
B205	20.167		28.69	na				
S206	9.083	5.6	13.74	na	20.76	0.15	127	7.0
B206	20.167		14.9	na				
S207	9.083	5.6	9.98	na	17.69	0.15	105	7.0
T208	9.5		12.79	na				
B208	20.167		16.1	na				
S208	9.083	5.6	12.28	na	19.62	0.15	127	7.0
200	20.167		55.85	na				
201	20.167		30.5	na				
202	20.167		25.27	na				
202A	20.167		23.19	na				
203	20.167		23.13	na				
203A	20.167		23.09	na				
204	20.167		23.1	na				
205	20.167		23.64	na				
2ND	20.167		57.85	na				
SPX	20.833		61.81	na				
SPX1	20.833		61.81	na				
SP13	20.833		61.92	na				
SP14	20.833		62.02	na				
SP15	10.25		66.64	na				
TOS	10.25		66.69	na				
BOS	5.0		69.03	na				
FLG	1.0		79.45	na				
CH1	-5.0		82.06	na				
UG1	-5.0		82.1	na				
UG2	-5.0		74.26	na	150.0			
UG3	-5.0		72.42	na				
CT1	-5.0		80.41	na				
CT2	-5.0		79.99	na				
CT3	-5.0		79.46	na				
CTY	2.5		77.04	na				

The maximum velocity is 17.01 and it occurs in the pipe between nodes BOS and FLG

Final Calculations - Hazen-Williams - 2007

Ranger Fire Inc
Summit Square III

Page 4
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S200 to B200	23.26 23.26	0.874 150.0 0.2769	3N	21.0 0.0 0.0	15.417 21.000 36.417	17.251 -4.800 10.085			K Factor = 5.60 Vel = 12.44	
B200 to 205	0.0 23.26	0.874 150.0 0.2770	1O	3.0 0.0 0.0	1.000 3.000 4.000	22.536 0.0 1.108			Vel = 12.44	
	0.0 23.26					23.644			K Factor = 4.78	
S201 to B201	20.66 20.66	0.874 150.0 0.2223	4N	28.0 0.0 0.0	19.584 28.000 47.584	13.606 -4.800 10.580			K Factor = 5.60 Vel = 11.05	
B201 to 203	0.0 20.66	0.874 150.0 0.2224	1N 1O	7.0 3.0 0.0	6.833 10.000 16.833	19.386 0.0 3.743			Vel = 11.05	
	0.0 20.66					23.129			K Factor = 4.30	
S202 to B202	22.89 22.89	0.874 150.0 0.2690	3N	21.0 0.0 0.0	15.501 21.000 36.501	16.714 -4.800 9.818			K Factor = 5.60 Vel = 12.24	
B202 to 202	0.0 22.89	0.874 150.0 0.2689	1N 1O	7.0 3.0 0.0	3.167 10.000 13.167	21.732 0.0 3.541			Vel = 12.24	
	0.0 22.89					25.273			K Factor = 4.55	
S203 to T204	18.30 18.3	0.874 150.0 0.1777	1N	7.0 0.0 0.0	13.167 7.000 20.167	10.679 -0.181 3.584			K Factor = 5.60 Vel = 9.79	
T204 to B204	20.58 38.88	1.101 150.0 0.2328	3N	21.0 0.0 0.0	15.834 21.000 36.834	14.082 -4.620 8.574			Vel = 13.10	
B204 to 204	0.0 38.88	1.101 150.0 0.2327	2O	10.0 0.0 0.0	11.750 10.000 21.750	18.036 0.0 5.062			Vel = 13.10	
	0.0 38.88					23.098			K Factor = 8.09	
S204 to T204	20.58 20.58	0.874 150.0 0.2210	1O	3.0 0.0 0.0	0.417 3.000 3.417	13.508 -0.181 0.755			K Factor = 5.60 Vel = 11.01	
	0.0 20.58					14.082			K Factor = 5.48	
S205 to B205	29.95 29.95	0.874 150.0 0.4420		0.0 0.0 0.0	11.084 0.0 11.084	28.595 -4.800 4.899			K Factor = 5.60 Vel = 16.02	
B205 to 201	0.0 29.95	0.874 150.0 0.4421	1O	3.0 0.0 0.0	1.083 3.000 4.083	28.694 0.0 1.805			Vel = 16.02	
	0.0 29.95					30.499			K Factor = 5.42	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 5
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
S206 to B206	20.76	0.874 150.0 0.2244	3N	21.0 0.0 0.0	5.584 21.000 26.584	13.739 -4.800 5.965			K Factor = 5.60 Vel = 11.10	
B206 to 203A	0.0	0.874 150.0 0.2244	1N 1O	7.0 3.0 0.0	26.500 10.000 36.500	14.904 0.0 8.189			Vel = 11.10	
	0.0 20.76					23.093			K Factor = 4.32	
S207 to T208	17.69	0.874 150.0 0.1669	1N	7.0 0.0 0.0	10.917 7.000 17.917	9.976 -0.181 2.990			K Factor = 5.60 Vel = 9.46	
T208 to B208	19.62	1.101 150.0 0.2156	3N	21.0 0.0 0.0	15.784 21.000 36.784	12.785 -4.620 7.932			Vel = 12.57	
B208 to 202A	0.0	1.101 150.0 0.2156	1N 1O	7.0 5.0 0.0	20.917 12.000 32.917	16.097 0.0 7.097			Vel = 12.57	
	0.0 37.31					23.194			K Factor = 7.75	
S208 to T208	19.62	0.874 150.0 0.2022	1O	3.0 0.0 0.0	0.417 3.000 3.417	12.275 -0.181 0.691			K Factor = 5.60 Vel = 10.49	
	0.0 19.62					12.785			K Factor = 5.49	
200 to 201	-126.04	2.003 150.0 -0.1112	3N 2F	33.0 5.186 0.0	189.750 38.186 227.936	55.847 0.0 -25.348			Vel = 12.83	
201 to 202	29.94	1.598 150.0 -0.2023	2N	18.0 0.0 0.0	7.834 18.000 25.834	30.499 0.0 -5.226			Vel = 15.37	
202 to 202A	22.90	1.598 150.0 -0.1223		0.0 0.0 0.0	17.000 0.0 17.000	25.273 0.0 -2.079			Vel = 11.71	
202A to 203	37.31	1.598 150.0 -0.0325		0.0 0.0 0.0	2.000 0.0 2.000	23.194 0.0 -0.065			Vel = 5.74	
203 to 203A	20.65	1.598 150.0 -0.0068		0.0 0.0 0.0	5.333 0.0 5.333	23.129 0.0 -0.036			Vel = 2.44	
203A to 204	20.76	1.598 150.0 0.0010		0.0 0.0 0.0	4.833 0.0 4.833	23.093 0.0 0.005			Vel = 0.88	
204 to 205	38.88	1.598 150.0 0.0485	1N	9.0 0.0 0.0	2.250 9.000 11.250	23.098 0.0 0.546			Vel = 7.10	
205 to 200	23.26	1.598 150.0 0.1057	6N 1O	54.0 8.0 0.0	242.667 62.000 304.667	23.644 0.0 32.203			Vel = 10.82	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 6
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 67.66					55.847			K Factor = 9.05	
200 to 2ND	193.70 193.7	3.26 120.0 0.0347	2E	18.815 0.0 0.0	38.749 18.815 57.564	55.847 0.0 1.998			Vel = 7.45	
2ND to SPX1	0.0 193.7	3.26 120.0 0.0347	3E 1T 1B 1S	28.223 20.159 13.44 21.503	39.167 83.325 122.492	57.845 -0.288 4.252			Vel = 7.45	
	0.0 193.70					61.809			K Factor = 24.64	
SPX to SPX1	0.0 0.0	6.357 120.0 0.0	1E 1T	17.603 37.72 0.0	120.333 55.323 175.656	61.809 0.0 0.0			Vel = 0	
SPX1 to SP13	193.70 193.7	6.357 120.0 0.0013	1E 1T	17.603 37.72 0.0	29.917 55.323 85.240	61.809 0.0 0.114			Vel = 1.96	
SP13 to SP14	0.0 193.7	6.357 120.0 0.0014	2E	35.205 0.0 0.0	33.500 35.205 68.705	61.923 0.0 0.093			Vel = 1.96	
SP14 to SP15	0.0 193.7	6.357 120.0 0.0013	1E	17.603 0.0 0.0	10.583 17.603 28.186	62.016 4.584 0.037			Vel = 1.96	
SP15 to TOS	0.0 193.7	6.357 120.0 0.0013	2E	35.205 0.0 0.0	7.583 35.205 42.788	66.637 0.0 0.057			Vel = 1.96	
TOS to BOS	0.0 193.7	6.357 120.0 0.0013	1T	37.72 0.0 0.0	5.250 37.720 42.970	66.694 2.274 0.058			Vel = 1.96	
BOS to FLG	0.0 193.7	2.157 120.0 0.2592	1Zaa	0.0 0.0 0.0	4.000 0.0 4.000	69.026 9.390 1.037			** Fixed Loss = 7.657 Vel = 17.01	
FLG to CH1	0.0 193.7	8.27 140.0 0.0003	1E	28.468 0.0 0.0	11.000 28.468 39.468	79.453 2.599 0.011			Vel = 1.16	
CH1 to UG1	0.0 193.7	7.68 150.0 0.0004	1T 1B	43.857 15.037 0.0	56.500 58.894 115.394	82.063 0.0 0.041			Vel = 1.34	
	0.0 193.70					82.104			K Factor = 21.38	
UG1 to UG2	-973.47 -973.47	7.68 150.0 -0.0070	4F 1T	45.11 43.857 0.0	1029.417 88.967 1118.384	82.104 0.0 -7.846			Vel = 6.74	
UG2 to UG3	150.00 -823.47	7.68 150.0 -0.0051	1T	43.857 0.0 0.0	312.417 43.857 356.274	74.258 0.0 -1.834			Qa = 150 Vel = 5.70	
UG3 to CT1	0.0 -823.47	7.68 150.0 -0.0051	1T 1Zcg	43.857 0.0 0.0	33.117 43.857 76.974	72.424 8.386 -0.396			** Fixed Loss = 8.386 Vel = 5.70	

Final Calculations - Hazen-Williams

Ranger Fire Inc
Summit Square III

Page 7
Date

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
CT1 to CT2	0.0 -823.47	11.2 150.0 -0.0008	1T	66.446 0.0 0.0	456.417 66.446 522.863	80.414 0.0 -0.429			Vel = 2.68	
CT2 to CT3	-343.70 -1167.17	11.2 150.0 -0.0016	1T	66.446 0.0 0.0	267.583 66.446 334.029	79.985 0.0 -0.522			Vel = 3.80	
CT3 to UG1	0.0 -1167.17	5.86 150.0 -0.0366	1T 1F 1Zcg	38.342 8.947 0.0	192.333 47.288 239.621	79.463 11.419 -8.778			* * Fixed Loss = 11.419 Vel = 13.88	
	0.0 -1167.17					82.104			K Factor = -128.81	
CT2 to CTY	343.70 343.7	6.16 140.0 0.0034	1E 1G 1T	20.084 4.304 43.037	22.500 67.425 89.925	79.985 -3.248 0.306			Vel = 3.70	
	0.0 343.70					77.043			K Factor = 39.16	