

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232518
Address: 4367 NE HIDEAWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, January 08, 2024

Corrective Action Required:

1	Misc	-Install tension strap adjacent to the garage portal opening -Fb fireplace and adjacent spaces from roof -Support ridges above front bedroom per plan -Fb basement wall from soffit -Provide (3)lvl beam between I beam in basement per plan
---	------	--

****OK TO INSULATE**

Comments: