

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231595
Address: 3246 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, January 08, 2024

Corrective Action Required:

1	Misc	-Missing fire blocking at top plate next to North East doors -Missing fire blocking top plate laundry -Missing fire blocking at wire chase behind master shower top and bottom
---	------	--

Comments: