CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20234931 Address: 1155 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Above Ceiling Inspection		Khanh Nguyen	Failed	Monday, January 08, 2024
Corrective	Action Required:			
1	Misc	-Plumbing vent shall be connect to a vent stack extended to outdoor -Add additional ceiling support. Provide information on how far the ceiling channels can span -Submit new mechanical installation plan		
		Above ceiling at rear of tenant space		
		-Close open electrical j-boxes		
		-Terminate all MC cables in j-boxes		
		-Secure all MC within 12" of all boxes		
		-Support all trades per code. Support flexible duct off ceiling grids at max 5 ft interval; PVC at 4 ft or less intervals; all water PEX lines every 32"; all MC cables at 6 ft or less intervals -Complete all trades		
		**Not ready for inspection	n	

Comments: