

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213809
Address: 3829 SW MARYVILLE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Not Ready	Wednesday, January 10, 2024

Corrective Action Required:

1	Misc	- no pier inspection on file - Provide (2) 1/2" through bolts or equivalent at the post to beam connections at deck - Provide security screws at exterior doors
---	------	---

Corrective Action Required:

2	Miscellaneous Correction	- no pier inspection on file - Provide (2) 1/2" through bolts or equivalent at the post to beam connections at deck - Provide security screws at exterior doors
---	--------------------------	---

(No improvements were made)
Walk you property before scheduling a inspection
Not ready for re inspection

Comments: