

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Wednesday, January 10, 2024

Informational:

1	FIRST FLOOR	-Shear wall nailing pattern and sheet rock band at stair side of Stair A1 -Sheet rock band at floor trusses stair side of Stair B1 -Sheet rock nailing pattern band at elevator A1
---	-------------	--

Informational:

2	SECOND FLOOR	-Shear wall nailing patten and sheet rock band at floor trusses Stair A1
---	--------------	--

Corrective Action Required:

3	THIRD FLOOR
---	-------------

Corrective Action Required:

4	FOURTH FLOOR
---	--------------

Corrective Action Required:

5	Miscellaneous Correction	-Have design professional clarify rating and detail for stairwell walls. Life safety plan shows 1 hour rating, details call for 2 hour wall where 4 or more floors connected
---	--------------------------	--

Comments: