

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20236311
Address: 420 SW LONGVIEW BLVD, Unit:200, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Shawn Hoffman	Not Ready	Thursday, January 11, 2024

Corrective Action Required:
1 Misc - NOT READY (PLUMBER STILL INSTALLING)

Comments: