

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234931
Address: 1155 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Partial	Thursday, January 11, 2024

Corrective Action Required:

1	Misc	-Engineer fix for damaged studs of demising wall-4 ft studs fasten to damaged studs per engineer drawing-OK. Plywood will be installed to reinforce the bottom 4 ft height of the wall. Call for inspection when ready
---	------	--

Comments: