

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234931
Address: 1155 NE RICE RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Thursday, January 11, 2024

Corrective Action Required:

1	Misc	-Provide access to mechanical units per code. Provide opening directly in front of the furnaces where the appliances are capable of being serviced and removed through the required opening. -Cannot use ceiling grid support wire to support MC cables -Support PVC @ 4 ft intervals -Secure water lines -Secure MC every 6 ft
---	------	---

Comments: