

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234540
Address: 2070 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------|------------|----------|---------------------------|
| In-wall Inspection | Robb Popp | Failed | Tuesday, January 16, 2024 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Provide bocca plates at top and bottom track where dwv is less than 1.25" to face of framing -Protect all dwv and pex within 1.25" of face of framing -Install grommets at all pex lines penetrating metal framing members |
|---|------|---|

Comments: