

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232039
Address: 1001 NW CHIPMAN RD, Unit:123, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, January 11, 2024

Corrective Action Required:

1	Misc	-Complete corrections for LSF -Install missing sprinkler escucheons -Cover open electrical at mechanical closet -Install air capture ducts at separate stations -Clarify specs for installed exhaust fan EF-1 (plans call for min 371 cfm), submittal shows 334 cfm -Provide hammer arrestors at pedicure station
---	------	---

Comments: