

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20220706
Address: 3120 SW SUMMIT VIEW TRL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, January 18, 2024

Corrective Action Required:

1	Misc	-all circuits in kitchen to be afci protected -obtain issued lawn irrigation permit -will check exterior and plot plan at time of snow melt. -provide access to water meter for inspection
---	------	---

Comments: