

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20236408

Address: 200 NE MISSOURI RD, Unit:303, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mitchell Schwarz	Partial	Monday, January 22, 2024

Corrective Action Required:

1	Misc	-All wiring methods in patient exam rooms, new or existing, must comply with NEC article 517 308 exam room okay
---	------	--

**Comments:**