

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20236408

Address: 200 NE MISSOURI RD, Unit:303, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mitchell Schwarz	Partial	Monday, January 22, 2024

Corrective Action Required:

1	Misc	-All wiring methods in patient exam rooms, new or existing, must comply with NEC article 517 **OK to cover non patient areas and exam room 308
---	------	---

Comments: