CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234022

Address: 2302 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Tuesday, January 23,

Residential 2024

Informational:

1 Misc Exterior garage portal and covered porch and patio OK to cover.

Corrective Action Required:

2 Miscellaneous

Correction -Anchor bolts in garage needs to be in the middle 1/3 of the sole plate (see N

garage wall)

-Master suite closet has a DWV that is cut in the top of the ceiling joist within

the allowable 2 inches (have engineer address fix)

Comments: