

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|------------|----------|-----------------------------|
| Rated Assembly Inspection | Robb Popp | Partial | Wednesday, January 24, 2024 |

Informational:

| | | |
|---|-------------|---|
| 1 | FIRST FLOOR | -Shear wall nailing pattern at stair side of Stair A1 -1st and second layer at joist space and 1st layer of walls at stair side, Stair A1 -Sheet rock band at floor trusses stair side of Stair B1 -Sheet rock nailing pattern at rim joist 1st and 2nd layer exterior side at elevator A1 |
|---|-------------|---|

Informational:

| | | |
|-----------------------------|--------------|--|
| 2 | SECOND FLOOR | -Shear wall nailing patten and sheet rock band at floor trusses Stair A1 |
| Corrective Action Required: | | |
| 3 | THIRD FLOOR | |
| Corrective Action Required: | | |
| 4 | FOURTH FLOOR | |

Comments: