



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113619, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Tuesday, August 09, 2011

Partial Correction  
1 MISC

OK TO COVER WHEN READY WALL FRAMING & IN-WALL SYSTEMS AT: NORTH & SOUTH DEMISING WALLS; WEST EXTERIOR WALL EXCEPT AT WIRING TO BE INSTALLED FOR EXIT SIGN;

<b>Underslab Plumbing Inspection - Commercial</b>	John Borns	Passed	Tuesday, August 09, 2011
---	------------	--------	--------------------------

**Comments: OK TO COVER WHEN READY UNDER-SLAB PVC DWV PIPING.**